




# COOLANT REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**WEG**  
 Component  
**Coolant**  
 Fluid  
**NOT GIVEN (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Corrosion

All component wear rates are normal.

### Contaminants

There is no indication of any contamination in the coolant. The amount and size of particulates present in the system are acceptable.

### Coolant Condition

The glycol level is acceptable. The pH level of this fluid is within the acceptable limits at 9.4.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0820262</b>	WC0820270	WC0820277
Sample Date	Client Info	<b>05 Dec 2023</b>	14 Nov 2023	07 Sep 2023
Machine Age	hrs	Client Info	<b>0</b>	0
Oil Age	hrs	Client Info	<b>0</b>	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	ABNORMAL	NORMAL

## PHYSICAL TEST RESULTS

method	limit/base	current	history1	history2	
Specific Gravity	*ASTM D1298	<b>1.061</b>	---	1.062	
pH	Scale 0-14	ASTM D1287	<b>9.40</b>	---	9.31
Nitrites	ppm	AP-053:2009	<b>0</b>	---	0
Reserve Alkalinity	Scale 0-20	*ASTM D1121	<b>---</b>	---	---
Percentage Glycol	%	ASTM D3321	<b>45.3</b>	---	45.4
Freezing Point	°F	ASTM D3321	<b>-24</b>	---	-24
Total Dissolved Solids			<b>0.0</b>	---	0.0
Carboxylate			<b>n/a</b>	---	pass

## CORROSION INHIBITORS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D6130	<b>16</b>	1	2
Phosphorus	ppm	ASTM D6130	<b>1725</b>	1671	2920
Boron	ppm	ASTM D6130	<b>2</b>	2	7
Molybdenum	ppm	ASTM D6130	<b>2</b>	3	2

## CORROSION

method	limit/base	current	history1	history2		
Iron	ppm	ASTM D6130	>15	<b>&lt;1</b>	0	<1
Aluminum	ppm	ASTM D6130	>10	<b>0</b>	0	0
Copper	ppm	ASTM D6130	>10	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D6130	>10	<b>&lt;1</b>	<1	0
Tin	ppm	ASTM D6130	>10	<b>&lt;1</b>	1	0
Zinc	ppm	ASTM D6130		<b>0</b>	<1	0

## CONTAMINANTS

method	limit/base	current	history1	history2		
Chlorine	ppm	ASTM D6130		<b>16</b>	8	8
Particles >4µm		ASTM D7647	>5000	<b>444</b>	▲ 8326	1514
Particles >6µm		ASTM D7647	>1300	<b>242</b>	▲ 4535	825
Particles >14µm		ASTM D7647	>160	<b>41</b>	▲ 772	140
Particles >21µm		ASTM D7647	>40	<b>14</b>	▲ 260	47
Particles >38µm		ASTM D7647	>10	<b>2</b>	▲ 40	7
Particles >71µm		ASTM D7647	>3	<b>0</b>	▲ 4	1
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<b>16/15/13</b>	▲ 20/19/17	18/17/14

## CARRIER SALTS






method	limit/base	current	history1	history2		
Sodium	ppm	ASTM D6130		<b>131</b>	125	205
Potassium	ppm	ASTM D6130		<b>5178</b>	5183	8612

## SCALE POTENTIAL

method	limit/base	current	history1	history2		
Calcium	ppm	ASTM D6130		<b>1</b>	2	<1
Magnesium	ppm	ASTM D6130		<b>&lt;1</b>	2	0









# COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	*Visual		Pink	---	Red
Coolant Appearance	*Visual	Clear	normal	---	normal
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0820262 **Received** : 08 Dec 2023  
**Lab Number** : 06030125 **Diagnosed** : 26 Dec 2023  
**Unique Number** : 10779916 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: COOL, KF, pH, PrtCount )

**UGI ENERGY SERVICES - LNG FACILITY**  
 80 ENERGY LN  
 MESHOPPEN, PA  
 US 18630  
 Contact: JOE BARRETT  
 jbarrett@ugies.com  
 T:  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)