


# PROBLEM SUMMARY

Sample Rating Trend






WATER



Area  
**RGS 10**  
 Machine Id  
**RGS 10 - 1 X AXIS ROLL GRINDER (S/N 16-2505-0121)**  
 Component  
**Gearbox**  
 Fluid  
**{not provided} (--- QTS)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise an early resample to confirm this situation.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>0.2	86.7	0.221	0.310
ppm Water	ppm	ASTM D6304	>2000	867000	2210	3100
Acid Number (AN)	mg KOH/g	ASTM D8045		3.239	0.15	0.14
Emulsified Water	scalar	*Visual	>0.2	0.2%	0.2%	0.2%
Free Water	scalar	*Visual		2.0	1.0	1.0
Visc @ 40°C	cSt	ASTM D445		0.87	70.1	69.6

Customer Id: OUTCALAL  
 Sample No.: RP0037971  
 Lab Number: 06054474  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We advise an early resample to confirm this situation.

HISTORICAL DIAGNOSIS

11 Jul 2023 Diag: Doug Bogart

WATER



We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.

view report



24 Feb 2023 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Appearance is hazy. Free water present. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid.

view report



24 Oct 2022 Diag: Don Baldrige

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. All component wear rates are normal. There is a high concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Area  
**RGS 10**  
 Machine Id  
**RGS 10 - 1 X AXIS ROLL GRINDER (S/N 16-2505-0121)**  
 Component  
**Gearbox**  
 Fluid  
**{not provided} (--- QTS)**

## DIAGNOSIS

### Recommendation

We advise an early resample to confirm this situation.

### Wear

All component wear rates are normal.

### Contamination

Sample consists almost entirely of water.

### Fluid Condition

The AN level is above the recommended limit. The oil viscosity is lower than normal.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>RP0037971</b>	RP0034963	RP0031343
Sample Date	Client Info		<b>05 Jan 2024</b>	11 Jul 2023	24 Feb 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		<b>82</b>	52	12
Iron	ppm	ASTM D5185m >200	<b>0</b>	3	2
Chromium	ppm	ASTM D5185m >15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >15	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	<1	0
Lead	ppm	ASTM D5185m >100	<b>&lt;1</b>	0	<1
Copper	ppm	ASTM D5185m >200	<b>0</b>	<1	<1
Tin	ppm	ASTM D5185m >25	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	7	2
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Calcium	ppm	ASTM D5185m	<b>1</b>	<1	0
Phosphorus	ppm	ASTM D5185m	<b>4</b>	38	37
Zinc	ppm	ASTM D5185m	<b>0</b>	3	0





## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>0</b>	2	<1
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Water	%	ASTM D6304 >0.2	<b>86.7</b>	0.221	0.310
ppm Water	ppm	ASTM D6304 >2000	<b>867000</b>	2210	3100

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>3.239</b>	0.15	0.14

# OIL ANALYSIS REPORT



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0037971 **Received** : 08 Jan 2024  
**Lab Number** : 06054474 **Diagnosed** : 29 Jan 2024  
**Unique Number** : 10820423 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: PQ )


**OUTOKUMPU STAINLESS USA**  
 HWY 43 N  
 CALVERT, AL  
 US 36513  
 Contact: MARIO JOHNSON  
 Mario.johnson@outokumpu.com  
 T: (251)321-4105  
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	LIGHT
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	0.2%	0.2%
Free Water	scalar	*Visual	0.2%	1.0	1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	▲ 0.87	70.1	69.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS

