

OIL ANALYSIS REPORT

Sample Rating Trend

ISO

MARYNEAL [200006807] Machine Id 87031 SITE 31

Component Wind Turbine Gearbox Fluid FUCHS RENOLIN CLP ISO 320 (650 LTR)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX06054860	NX009596	
Sample Date		Client Info		13 Oct 2023	30 Sep 2021	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				ATTENTION	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184	>80	13	14	
Iron	ppm	ASTM D5185m	>150	9	6	
Chromium	ppm	ASTM D5185m	>5	0	<1	
Nickel	ppm	ASTM D5185m	>10	0	0	
Titanium	ppm	ASTM D5185m	>10	0	0	
Silver	ppm	ASTM D5185m		0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m		<1	<1	
Copper	ppm	ASTM D5185m	>50	0	<1	
Tin	ppm	ASTM D5185m		0	<1	
Antimony	ppm	ASTM D5185m	>3		<1	
Vanadium	ppm	ASTM D5185m	20	0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		6	6	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m		0	0	
Calcium	ppm	ASTM D5185m		11	19	
Phosphorus	ppm	ASTM D5185m		185	196	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur		ASTM D5185m		4696	3903	
	ppm		11 1. 0			
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		10	8	
Sodium	ppm	ASTM D5185m		6	0	
Potassium	ppm	ASTM D5185m		0	11	
Water	%	ASTM D6304		0.003	0.001	
ppm Water	ppm	ASTM D6304	>500	28	12.8	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		16352	22291	
Particles >6µm		ASTM D7647	>2500	4993	▲ 8299	
Particles >14µm		ASTM D7647	>320	253	1 114	
Particles >21µm		ASTM D7647	>80	37	A 320	
Farticles >2 1µm						
Particles >38µm		ASTM D7647	>20	1	6	
		ASTM D7647 ASTM D7647	>20 >4	1 0	6 0	



OIL ANALYSIS REPORT

Particle Trend	FLUID DEGRADA	AHON	method	limit/base	current	history1	history
4μm 5μm	Acid Number (AN)	mg KOH/g	ASTM D8045		0.44	0.37	
	VISUAL		method	limit/base	current	history1	history
	White Metal	scalar	*Visual	NONE	NONE	LIGHT	
\$\$2,552,250,460,460,446,444,454,465,446,454,460,446,454,465,446,454,446,446,446,446,446	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
	Precipitate	scalar	*Visual	NONE	NONE	NONE	
Sep 30/21 - Oct13/23 -	Silt	scalar	*Visual	NONE	NONE	NONE	
Sep.	Debris	scalar	*Visual	NONE	NONE	NONE	
Water (KF)	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
· · ·	Appearance	scalar	*Visual	NORML	NORML	NORML	
Severe	Odor Emulsified Water	scalar	*Visual *Visual	NORML	NORML	NORML	
	Free Water	scalar scalar	*Visual	>0.05	NEG NEG	NEG NEG	
Abnormal	FLUID PROPERT			limit/baco		_	histor
			method	limit/base	current	history1	history
	Visc @ 40°C	cSt	ASTM D445	320	314	324	
Sep 30/21 Sep 30/21 0 ct 13/23	SAMPLE IMAGE	S	method	limit/base	current	history1	history
² Q	Color					Dar With With With Mate	no imag
Severe	Color						no imag
				1			
Abnormal	Bottom						no imag
				l l			
	GRAPHS						
Sep 30/21 - Oct13/23 -					Particle Count	:	
Sep	10 iron]			491,520			
Water (KF)	E 5-			122,880			
				30,720			
Severe D		******		= 7,680			
	Sep30/21			0ct13/23 0ct13/23 1920 1920 1920 1920 1920 1920 1920 1920		·	
Abnormal				Cles (p	1		
	Non-ferrous Meta	S		ottred to			
	copper						
0/21	E 5-			a 30			
Sep 30/21				8	Sizven al		
Viscosity @ 40°C	0/21			2/23			
Abnormal	Sep30/2			2 Oct13/23			1
	Viscosity @ 40°C			4	ہوں Acid Number	14μ 21μ	38µ 7
	360 Abnormal			(⁰ / ₂ 3.00 MOX			
Base	340			ରୁ ଜୁ ଅ.୦୦	Abnormal		
	王 320			یں۔ 1.00			
Abnormal	Ponolina			4.00.0 Part 1.00	Abnormal		
	280			-00.0 Pc: 4	0/21		
8ep 30,21	Sep30/21			0ct13/23	Sep30/2		
Laboratory Sample No. Lab Number Unique Number Unique Number Test Package To discuss this sample report, * - Denotes test methods that d	: 06054860 : 10820809 : IND 2 (Additional T contact Customer Serv	Recieved Diagnose Diagnost ests: KF, ice at 1-8	d : 08 . ed : 10 . ician : Dor PQ, PrtCour 00-237-1369	Jan 2024 Jan 2024 n Baldridge nt) 9.	300 SOL	NORDEX U ITH WACKER DRI Contact: DE DLinehan@norc	VE, SUITE CHICAGO US 60 VIN LINEI

Contact/Location: DEVIN LINEHAN - NORDEX