




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
DENNIS BOTTORFF
 Machine Id
[DENNIS BOTTORFF] 001 569953-1
 Component
Port Main Engine
 Fluid
CHEVRON DELO 710 LS (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		MW0064504	MW0027146	MW0041478
Sample Date	Client Info		01 Jan 2024	01 Dec 2023	01 Nov 2023
Machine Age	hrs	Client Info	40852	40108	39388
Oil Age	hrs	Client Info	40852	40108	39388
Oil Changed	Client Info		N/A	Not Changd	Not Changd
Sample Status			NORMAL	ATTENTION	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>0.1	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >75	20	31	19
Chromium	ppm	ASTM D5185m >8	2	1	2
Nickel	ppm	ASTM D5185m >2	<1	0	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >15	2	2	2
Lead	ppm	ASTM D5185m >18	3	4	4
Copper	ppm	ASTM D5185m >80	17	22	14
Tin	ppm	ASTM D5185m >14	3	4	3
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	56	▲ 60	66
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	51	57	59
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	57	88	98
Calcium	ppm	ASTM D5185m	3297	3272	3218
Phosphorus	ppm	ASTM D5185m	71	83	105
Zinc	ppm	ASTM D5185m	51	▲ 91	122
Sulfur	ppm	ASTM D5185m	2413	2432	2506

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >20	5	5	5
Sodium	ppm	ASTM D5185m >75	2	4	6
Potassium	ppm	ASTM D5185m >20	3	1	2

INFRA-RED



	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >3	1.1	1.5	1
Nitration	Abs/cm	*ASTM D7624 >20	8.7	9.6	9.4
Sulfation	Abs/.1mm	*ASTM D7415 >30	17.2	19.3	18.3

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	9.2	10.1	10.4
Base Number (BN)	mg KOH/g	ASTM D2896 10.5	9.48	▲ 12.54	9.07







OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	15.5	14.1	14.9	14.2

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : MW0064504 **Recieved** : 08 Jan 2024
Lab Number : 06055039 **Diagnosed** : 10 Jan 2024
Unique Number : 10820988 **Diagnostician** : Sean Felton
Test Package : MAR 2 (Additional Tests: PrtCount)

INGRAM BARGE
 900 S 3RD ST
 PADUCAH, KY
 US 42003
 Contact: ANTHONY VAN CURA
 anthony.vancura@ingrambarga.com
 T: (270)415-4467
 F: (615)695-3697

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)