

## **OIL ANALYSIS REPORT**

Sample Rating Trend

## NORMAL

#### Area ENGINE ROOM Machine Id RC15 (S/N 160301)

Component Refrigeration Compressor Fluid CAMCO 717 HT (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear


All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The condition of the oil is acceptable for the time in service.






#### v2012 Nov2013 0ct2014 Jan2016 Jul2017 Jun2018 Aug2019 Apr2022 0ct2023

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		WC0884902	WC0857523	WC0835319	
Sample Date		Client Info		27 Dec 2023	07 Oct 2023	10 Jul 2023	
Machine Age	hrs	Client Info		27762	0	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				NORMAL	NORMAL	NORMAL	
CONTAMINATION	١	method	limit/base	current	history1	history2	
Water		WC Method	>0.01	NEG	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>8	3	<1	0	
Chromium	ppm	ASTM D5185m	>2	<1	3	0	
Nickel	ppm	ASTM D5185m		<1	0	0	
Titanium	ppm	ASTM D5185m		<1	0	<1	
Silver	ppm	ASTM D5185m	>2	0	0	0	
Aluminum	ppm	ASTM D5185m	>3	2	0	<1	
Lead	ppm	ASTM D5185m	>2	<1	0	0	
Copper	ppm	ASTM D5185m	>8	<1	0	0	
Tin	ppm	ASTM D5185m	>4	<1	0	0	
Vanadium	ppm	ASTM D5185m		0	0	<1	
Cadmium	ppm	ASTM D5185m		<1	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0	
Barium	ppm	ASTM D5185m		0	0	0	
Molybdenum	ppm	ASTM D5185m		<1	0	0	
Manganese	ppm	ASTM D5185m		<1	0	<1	
Magnesium	ppm	ASTM D5185m		0	0	0	
Calcium	ppm	ASTM D5185m		2	2	<1	
Phosphorus	ppm	ASTM D5185m		22	0	21	
Zinc	ppm	ASTM D5185m		0	0	0	
Sulfur	ppm	ASTM D5185m		0	0	20	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>15	1	0	0	
Sodium	ppm	ASTM D5185m		<1	0	<1	
Potassium	ppm	ASTM D5185m	>20	1	<1	0	
VISUAL		method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	LIGHT	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG	
Free Water	scalar	*Visual		NEG	NEG	NEG	
1:25:16) Rev: 1	Contact/Location: ERIC KLINE - LEPGRE						

Contact/Location: ERIC KLINE - LEPGRE



# **OIL ANALYSIS REPORT**



с	FLUID PROPER	TIES	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445	69	67.0	65.6	66.9	
1	SAMPLE IMAGE	ES	method	limit/base	current	history1	history2	
Jan26/16 Jun20/17 Jun18/18 - Aug15/19 - Apr5/22 - Oct7/23 -	Color						no image	
	Bottom						no image	
	GRAPHS							
	Ferrous Alloys							
	9 - iron 							
	8 - new nickel							
	6							
	4							
	3-2	<u>_</u>		N				
	1 Jan	$\smile \iota$	Ma	AL.				
	Nov17/12 Nov6/13 Oct24/14	Jul20/17	Aug 15/19 Apr5/22	0ct7/23				
	ු ු ප ප ල Non-ferrous Meta		Aug	ō				
	<sup>10</sup>	ais	10101000000					
	9 - copper 8 - in lead							
	7-6-							
	5-							
	4	1						
	2	Ν.						
	1 All	1 mg	AAA	1				
	Nov17/12 Nov6/13 Oct24/14 Jan26/16	Jul20/17 Jun18/18	Aug15/19 Apr5/22	0ct7/23				
z	Viscosity @ 40°C		A					
	Abnormal							
	75 -							
	70 - Base		~~~~					
54 (40 °C	Abnormal	<b>_</b>		$\sim$				
~	60 -	1						
	55	۷	· · · · · · · · · · · · ·					
	50	8	2					
	Nov17/12 Nov6/13 Oct24/14 Jan26/16	Jul20/17 Jun18/18	Aug15/19 Apr5/22	0ct7/23				
Laboratory Sample No. Lab Number Unique Number	: WearCheck USA - : WC0884902 : 06055120 : 10821069		son Ave., Ca I : 08 c ed : 10 c	ry, NC 27513 Jan 2024 Jan 2024 athan Hester		G	<b>DS-GREELEY</b> 302 1ST AVE REELEY, CO 8 80631-5909	
	: IND 1	-	0			Contact: ERIC F EKLINE@LEPRINOFOODS		
<ul> <li>A discuss this sample report, c</li> <li>* - Denotes test methods that ar</li> <li>Statements of conformity to speci</li> </ul>	e outside of the ISO	17025 sco	pe of accred	litation.			FOODS.COM T: 970)347-5190	

Contact/Location: ERIC KLINE - LEPGRE