OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Machine Id
HYD OIL TURBINE
Component
Hydraulic System
Fluid
CHEVRON GST OIL ISO 32 (--- QTS)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor. Please specify the component make and model with your next sample.

Wear
All component wear rates are normal.

Contamination
The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0722115**	WC03214934	WCM2072460
Sample Date		Client Info		**05 Jan 2024**	18 Jan 2013	23 Jan 2008
Machine Age	yrs	Client Info		**33**	0	0
Oil Age	yrs	Client Info		**5**	0	0
Oil Changed		Client Info		**N/A**	N/A	Not Changd
Sample Status				**NORMAL**	ABNORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	**0**	1	2
Chromium	ppm	ASTM D5185m	>10	**0**	<1	0
Nickel	ppm	ASTM D5185m	>10	**0**	0	0
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>10	**0**	<1	0
Lead	ppm	ASTM D5185m	>10	**0**	2	1
Copper	ppm	ASTM D5185m	>75	**<1**	<1	<1
Tin	ppm	ASTM D5185m	>10	**0**	0	2
Antimony	ppm	ASTM D5185m		**---**	2	2
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	<1
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**0**	<1	0
Manganese	ppm	ASTM D5185m		**<1**	0	0
Magnesium	ppm	ASTM D5185m		**0**	0	0
Calcium	ppm	ASTM D5185m		**0**	<1	3
Phosphorus	ppm	ASTM D5185m		**100**	21	6
Zinc	ppm	ASTM D5185m		**37**	6	6
Sulfur	ppm	ASTM D5185m		**877**	235	162

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>20	**<1**	<1	0
Sodium	ppm	ASTM D5185m		**<1**	<1	1
Potassium	ppm	ASTM D5185m	>20	**0**	0	0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	**4318**	4826	2814
Particles >6µm		ASTM D7647	>1300	**1102**	▲ 2629	▲ 1533
Particles >14µm		ASTM D7647	>160	**72**	▲ 447	▲ 261
Particles >21µm		ASTM D7647	>40	**21**	▲ 151	▲ 88
Particles >38µm		ASTM D7647	>10	**2**	▲ 23	▲ 13
Particles >71µm		ASTM D7647	>3	**0**	▲ 2	▲ 1
Oil Cleanliness		ISO 4406 (c)	>19/17/14	**19/17/13**	▲ 19/19/16	▲ 19/18/15

OIL ANALYSIS REPORT

Particle Trend



Acid Number



Viscosity @ 40°C



Particle Trend



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.07**	0.124	0.097

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	30.4	**30.3**	34.76	35.00

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				*no image*	*no image*
Bottom				*no image*	*no image*

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0722115
Lab Number : 06056627
Unique Number : 10822576
Test Package : MOB 2

Recieved : 10 Jan 2024
Diagnosed : 11 Jan 2024
Diagnostician : Wes Davis

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T.E.S. FILER CITY STATION
700 MEE ST.
FILER CITY, MI
US 49634
Contact: CLARK JOHNSON
clark.johnson@cmsenergy.com
T: (231)723-6573
F: (231)723-6630