

OIL ANALYSIS REPORT

KAESER ASD 30 5992232 (S/N 1356)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear


All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC122914	KC97281	KC99816
Sample Date		Client Info		14 Dec 2023	08 Mar 2022	23 Sep 2021
Machine Age	hrs	Client Info		30505	20222	17995
Oil Age	hrs	Client Info		0	2226	6000
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m		0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	<1	<1	2
Lead	ppm		>10	0	<1	<1
Copper	ppm	ASTM D5185m		8	5	10
Tin	ppm	ASTM D5185m		<1	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ррш		11 11 11		-	-
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	4	3	5
Calcium	ppm	ASTM D5185m	2	1	0	0
Phosphorus	ppm	ASTM D5185m		4	0	2
Zinc	ppm	ASTM D5185m		28	22	19
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		<1	9	0
Potassium	ppm	ASTM D5185m	>20	<1	4	<1
Water	%	ASTM D6304	>0.05	A 0.148	0.003	0.008
ppm Water	ppm	ASTM D6304	>500	1480	34.0	89.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1696	9287	3238
Particles >6µm		ASTM D7647	>1300	924	<u> </u>	1022
Particles >14µm		ASTM D7647	>80	1 57	▲ 252	77
Particles >21µm		ASTM D7647		▲ 53	▲ 83	18
Particles >38µm		ASTM D7647	>4	▲ 8	4	0
Particles >71µm		ASTM D7647		1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	▲ 18/17/14	▲ 19/15	17/13
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.39	0.43	0.380
	ing NOTI/g	101W D0043	0.7	0.05	00	0.000


Contact/Location: Service Manager - SWNLYO




OIL ANALYSIS REPORT











स

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.1	44.4	44.5
SAMPLE IMAGES		method	limit/base	current	history1	history2

Color



Bottom



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: Service Manager - SWNLYO

F: