


# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**KAESER BSD 50 4387134 (S/N 1138)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCPA008703</b>	KCP47336D	KCP38307
Sample Date	Client Info		<b>16 Nov 2023</b>	15 Nov 2022	15 Mar 2022
Machine Age	hrs	Client Info	<b>29417</b>	1018	28327
Oil Age	hrs	Client Info	<b>0</b>	1407	390
Oil Changed	Client Info		<b>N/A</b>	Not Changd	Not Changd
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	<1	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>3</b>	3	2
Tin	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Antimony	ppm	ASTM D5185m	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m 90	<b>40</b>	24	53
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m 90	<b>58</b>	64	78
Calcium	ppm	ASTM D5185m 2	<b>2</b>	1	2
Phosphorus	ppm	ASTM D5185m	<b>4</b>	6	2
Zinc	ppm	ASTM D5185m	<b>0</b>	10	3
Sulfur	ppm	ASTM D5185m	<b>18986</b>	19275	17077

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>&lt;1</b>	0	0
Sodium	ppm	ASTM D5185m	<b>4</b>	15	10
Potassium	ppm	ASTM D5185m >20	<b>3</b>	6	<1
Water	%	ASTM D6304 >0.05	<b>▲ 0.217</b>	0.008	<b>▲ 0.481</b>
ppm Water	ppm	ASTM D6304 >500	<b>▲ 2170</b>	87.1	<b>▲ 4810</b>






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>609</b>	32359	---
Particles >6µm	ASTM D7647 >1300		<b>332</b>	<b>▲ 12644</b>	---
Particles >14µm	ASTM D7647 >80		<b>56</b>	<b>▲ 807</b>	---
Particles >21µm	ASTM D7647 >20		<b>19</b>	<b>▲ 121</b>	---
Particles >38µm	ASTM D7647 >4		<b>3</b>	<b>▲ 4</b>	---
Particles >71µm	ASTM D7647 >3		<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c) >--/17/13		<b>16/16/13</b>	<b>▲ 22/21/17</b>	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.41</b>	0.39	0.402


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	47.0	48.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA008703 **Received** : 10 Jan 2024  
**Lab Number** : 06056652 **Diagnosed** : 16 Jan 2024  
**Unique Number** : 10822601 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**PREFIX**  
 3500 JOSLYN RD  
 AUBURN HILLS, MI  
 US 48326  
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: