

OIL ANALYSI

KAESER ASD30 5979459 (S/N

Oil Cleanliness

Acid Number (AN)

FLUID DEGRADATION

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Machine In

Component

Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. Excessive free water present.

Fluid Condition

The AN level is acceptable for this fluid.

Sample Rating Trend						WATER
S/N 1354)			April 13	Nerduzz		
SAMPLE INFORM	/ ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA011251	KCP00384	
Sample Date		Client Info		15 Nov 2023	11 Apr 2019	
Machine Age	hrs	Client Info		12148	2214	
Oil Age	hrs	Client Info		0	2214	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron			>50	0	1	
Chromium	ppm ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	9	10	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
			in in base			
Boron	ppm	ASTM D5185m	00	0	<1	
Barium	ppm	ASTM D5185m	90	0	<1	
Molybdenum	ppm	ASTM D5185m		0 <1	0 <1	
Manganese Magnesium	ppm ppm	ASTM D5185m ASTM D5185m	90	7	38	
Calcium	ppm	ASTM D5185m	2	0	<1	
Phosphorus	ppm	ASTM D5185m	2	4	2	
Zinc	ppm	ASTM D5185m		31	40	
Sulfur	ppm	ASTM D5185m		16353	24413	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon		ASTM D5185m	>25		<1	
Sodium	ppm ppm	ASTM D5185m	>20	0	18	
Potassium	ppm	ASTM D5185m	>20	2 <1	8	
Water	%	ASTM D3103III	>0.05	A 0.086	0.014	
ppm Water	ppm	ASTM D6304	>500	▲ 860	140	
						history 0
FLUID CLEANLIN		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	1000		6251	
Particles >6µm		ASTM D7647	>1300		▲ 1495	
Particles >14µm		ASTM D7647	>80		50	
Particles >21µm		ASTM D7647	>20		7	
Particles >38µm		ASTM D7647	>4		0	
Particles >71µm		ASTM D7647	>3		0	

Report Id: ANKCHE [WUSCAR] 06056667 (Generated: 01/11/2024 15:04:45) Rev: 1

method mg KOH/g ASTM D8045 0.4

ISO 4406 (c) >--/17/13

limit/base

0.38 0.442 Contact/Location: Service Manager - ANKCHE

history1

18/13

current

Page 1 of 2

history2



OIL ANALYSIS REPORT

method


limit/base


current


history1


history2

VISUAL









Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: Service Manager - ANKCHE