


OIL ANALYSIS REPORT

Sample Rating Trend



ISO

6081148 (S/N 1029)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

רו	ΙΔ	(-1)	V۲	15	SIS
	-	ш	W	ノし	טוכ

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Doc202:	0 Jan 2022	Dec2022 De	c2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA010192	KCP49372	KCP43403
Sample Date		Client Info		18 Dec 2023	07 Dec 2022	07 Jan 2022
Machine Age	hrs	Client Info		7345	5711	4198
Oil Age	hrs	Client Info		0	1538	1651
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ATTENTION	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	3	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	23
Barium	ppm	ASTM D5185m	90	19	23	38
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	100	24	79	82
Calcium	ppm	ASTM D5185m	0	0	<1	3
Phosphorus	ppm	ASTM D5185m	0	4	5	3
Zinc	ppm	ASTM D5185m	0	0	4	8
Sulfur	ppm	ASTM D5185m	23500	18308	18926	17646
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		<1	12	15
Potassium	ppm	ASTM D5185m	>20	<1	7	9
Water	%	ASTM D6304	>0.05	0.014	0.007	0.007
ppm Water	ppm	ASTM D6304	>500	142	77.2	78.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		2778	843	18904
Particles >6µm		ASTM D7647	>1300	799	173	<u>▲</u> 6254
Particles >14μm		ASTM D7647	>80	86	21	<u>^</u> 226
Particles >21µm		ASTM D7647	>20	27	11	▲ 35
Particles >38μm		ASTM D7647	>4	0	2	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/14	17/15/12	<u>^</u> 20/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Sample No. Lab Number **Unique Number**

: 06056714

: KCPA010192 : 10822663

Recieved : 10 Jan 2024 Diagnosed : 11 Jan 2024

Diagnostician : Doug Bogart Test Package : IND 2 (Additional Tests: KF, PrtCount)

Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

LOUISVILLE, CO

Contact: Service Manager

US 80027

T: F: