

OIL ANALYSIS REPORT



WEAR

KAESER ESD 300 8780570 (S/N 1741)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Sep2023	Dec2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121045	KC110817	
Sample Date		Client Info		18 Dec 2023	20 Sep 2023	
Machine Age	hrs	Client Info		2330	1294	
Oil Age	hrs	Client Info		0	1294	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	<u> </u>	△ 91	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	0	0	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		4	0	
Zinc	ppm	ASTM D5185m		0	0	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	<1	1	
Water	%	ASTM D6304	>0.05	0.008	0.007	
ppm Water	ppm	ASTM D6304	>500	81	76.2	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		7632	91159	
Particles >6µm		ASTM D7647	>1300	<u> </u>	43868	
Particles >14μm		ASTM D7647	>80	<u> </u>	▲ 572	
Particles >21µm		ASTM D7647	>20	<u>^</u> 22	▲ 77	
Particles >38µm		ASTM D7647	>4	0	<u> </u>	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/14	2 4/23/16	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.42

0.36



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: KC121045 : 06056721

: 10822670 : IND 2

: 10 Jan 2024 Recieved Diagnosed Diagnostician

: 12 Jan 2024 : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

3000 E FRONT ST

MONROE, MI US 48161 Contact: