

## **OIL ANALYSIS REPORT**

Sample Rating Trend

**WATER** 

# KAESER AS 31 1406263 (S/N 1053)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA002579	KCP23270	
Sample Date		Client Info		05 Jan 2024	05 Nov 2019	
Machine Age	hrs	Client Info		17573	9438	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	SEVERE	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	3	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	7	4	
Tin	ppm	ASTM D5185m	>10	<1	0	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	27	8	
Barium Molybdenum	ppm ppm	ASTM D5185m ASTM D5185m	90	27 0	8	
			90			
Molybdenum	ppm	ASTM D5185m	90	0	0	
Molybdenum Manganese	ppm	ASTM D5185m ASTM D5185m	90	0 <1	0 <1	
Molybdenum Manganese Magnesium	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	90	0 <1 46	0 <1 48	
Molybdenum Manganese Magnesium Calcium	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	90	0 <1 46 <1	0 <1 48 <1	
Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	90	0 <1 46 <1 4	0 <1 48 <1 19	
Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	90	0 <1 46 <1 4 3	0 <1 48 <1 19	
Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m method	90	0 <1 46 <1 4 3 18839	0 <1 48 <1 19 2 18178	  
Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m method	90 2	0 <1 46 <1 4 3 18839 current	0 <1 48 <1 19 2 18178 history1	    history2
Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m  method ASTM D5185m	90 2	0 <1 46 <1 4 3 18839 current <1	0 <1 48 <1 19 2 18178 history1 2	    history2
Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	90 2 limit/base >25	0 <1 46 <1 4 3 18839 current <1 6	0 <1 48 <1 19 2 18178 history1 2 2	    history2
Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	90 2 limit/base >25 >20	0 <1 46 <1 4 3 18839 current <1 6 2	0 <1 48 <1 19 2 18178 history1 2 2 <1	   history2
Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium Potassium Water	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	90 2 limit/base >25 >20 >0.05	0 <1 46 <1 4 3 18839 current <1 6 2	0 <1 48 <1 19 2 18178 history1 2 2 <1 △ 0.540	history2



### **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA002579

: 06056736 : 10822685 Recieved : 10 Jan 2024 Diagnosed

: 11 Jan 2024 Diagnostician : Doug Bogart

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**LEGACY INDUSTRIAL ELECTRIC** 

301 PARK ST TROY, MI US 48083

Contact: Service Manager

T: F: