OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Machine Id
RC1 (200HP) (S/N 5372)
Component
Refrigeration Compressor
Fluid
USPI 1009-68 SC (--- GAL)

DIAGNOSIS

▲ Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

▲ Contamination
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**USP0005296**	USP0001908	---
Sample Date		Client Info		**01 Jan 2024**	17 Sep 2023	---
Machine Age	hrs	Client Info		**47102**	0	---
Oil Age	hrs	Client Info		**0**	18000	---
Oil Changed		Client Info		**N/A**	N/A	---
Sample Status				**ATTENTION**	NORMAL	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	**8**	7	---
Chromium	ppm	ASTM D5185m	>2	**0**	0	---
Nickel	ppm	ASTM D5185m		**0**	0	---
Titanium	ppm	ASTM D5185m		**0**	0	---
Silver	ppm	ASTM D5185m	>2	**0**	0	---
Aluminum	ppm	ASTM D5185m	>3	**0**	0	---
Lead	ppm	ASTM D5185m	>2	**0**	0	---
Copper	ppm	ASTM D5185m	>8	**0**	<1	---
Tin	ppm	ASTM D5185m	>4	**<1**	0	---
Vanadium	ppm	ASTM D5185m		**0**	<1	---
Cadmium	ppm	ASTM D5185m		**0**	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	---
Barium	ppm	ASTM D5185m		**0**	0	---
Molybdenum	ppm	ASTM D5185m		**0**	0	---
Manganese	ppm	ASTM D5185m		**<1**	<1	---
Magnesium	ppm	ASTM D5185m		**0**	0	---
Calcium	ppm	ASTM D5185m		**0**	0	---
Phosphorus	ppm	ASTM D5185m		**0**	0	---
Zinc	ppm	ASTM D5185m		**0**	0	---
Sulfur	ppm	ASTM D5185m	50	**4**	19	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	**<1**	2	---
Sodium	ppm	ASTM D5185m		**0**	0	---
Potassium	ppm	ASTM D5185m	>20	**<1**	0	---
Water	%	ASTM D6304	>0.01	**0.003**	0.003	---
ppm Water	ppm	ASTM D6304	>100	**35**	33.7	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	▲ **18684**	9622	---
Particles >6µm		ASTM D7647	>2500	▲ **3295**	1674	---
Particles >14µm		ASTM D7647	>320	**82**	59	---
Particles >21µm		ASTM D7647	>80	**16**	22	---
Particles >38µm		ASTM D7647	>20	**0**	5	---
Particles >71µm		ASTM D7647	>4	**0**	2	---
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ **21/19/14**	20/18/13	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	**0.013**	0.015	---

OIL ANALYSIS REPORT

Particle Trend



Water (KF)



Acid Number



Water (KF)



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	---
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	---
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	---
Silt	scalar	*Visual	NONE	**NONE**	NONE	---
Debris	scalar	*Visual	NONE	**NONE**	NONE	---
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	---
Appearance	scalar	*Visual	NORML	**NORML**	NORML	---
Odor	scalar	*Visual	NORML	**NORML**	NORML	---
Emulsified Water	scalar	*Visual	>0.01	**NEG**	NEG	---
Free Water	scalar	*Visual		**NEG**	NEG	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	67	**67.5**	68.0	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					*no image*
Bottom					*no image*

GRAPHS

Ferrous Alloys



Non-ferrous Metals

Viscosity @ 40°C



Particle Count



Acid Number



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP0005296
Lab Number : 06056762
Unique Number : 10822711
Test Package : IND 2

Recieved : 10 Jan 2024
Diagnosed : 12 Jan 2024
Diagnostician : Doug Bogart

Certificate L2367

PLAINS DAIRY AMARAILLO
300 N TAYLOR
AMARILLO, TX
US 79105
Contact: ROBERT BURT

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: