

# **OIL ANALYSIS REPORT**

## DURATECH HI SULLAIR 201204230014 - DECATUR MEMORIAL HOSP Component

Compressor

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06056798	UCH05015911	
Sample Date		Client Info		16 Nov 2023	10 Jun 2020	
Machine Age	hrs	Client Info		61428	45828	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	N/A	
Sample Status				NORMAL	NORMAL	
CONTAMINATION	۷	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	4	8	
Chromium	ppm	ASTM D5185m		0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	<1	
Aluminum	ppm	ASTM D5185m	>25	1	1	
Lead	ppm	ASTM D5185m	>25	0	<1	
Copper	ppm	ASTM D5185m	>50	2	4	
Tin	ppm	ASTM D5185m	>15	0	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	2	
Barium	ppm	ASTM D5185m		1	2	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m		0	<1	
Calcium	ppm	ASTM D5185m		0	1	
Phosphorus	ppm	ASTM D5185m		190	177	
Zinc	ppm	ASTM D5185m		52	15	
Sulfur	ppm	ASTM D5185m		210	171	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	8	
Sodium	ppm	ASTM D5185m		<1	2	
Potassium	ppm	ASTM D5185m	>20	0	<1	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.51	0.408	



# **OIL ANALYSIS REPORT**

VISUAL



		White Metal	scalar	*Visual	NONE	NONE	NONE	
		Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
		Precipitate	scalar	*Visual	NONE	NONE	NONE	
		Silt	scalar	*Visual	NONE	NONE	NONE	
		Debris	scalar	*Visual	NONE	NONE	NONE	
	5	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
	Nov16/23	Appearance	scalar	*Visual	NORML	NORML	NORML	
	N	Odor Emulsified Water	scalar	*Visual	NORML	NORML	NORML	
			scalar	*Visual	>0.1	NEG	NEG	
		Free Water		*Visual		NEG	NEG	
		FLUID PROPER		method	limit/base	current	history1	history2
		Visc @ 40°C	cSt	ASTM D445		45.6	46.0	
		SAMPLE IMAGE	S	method	limit/base	current	history1	history2
	Nov16/23	Color						no image
		Bottom						no image
	шd	Non-ferrous Meta	ls		Nov16/23			
	cSt (40°C)	Viscosity @ 40°C			Acid Number (mg KOH(g) 10.0 10.0 10.0 10.0 10.0 10.0 10.0 10.	Acid Number		
		40 - Abnormal 35			Nov16/23	2		Movel 6.73
Increase L2367 Sar Sar Lab Unic Sar Lab	mple No. o Number que Number st Package	: UCH06056798 : 06056798 : 10822747 : IND 2	Recieved Diagnose Diagnosti				HTE TECHNOLOGIE 2021 CONGRESSIONAL D ST LOUIS, M US 6314 Contact: JOSH DYRLAN josh.dyrland@htetech.co T: (314)731-444 F: (314)731-442	

Contact/Location: JOSH DYRLAND - UCHTESTL