




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
PARTS
 Machine Id
ACCU PRESS PRT-PBR-10 (S/N 8579)
 Component
Hydraulic System
 Fluid
CASTROL HYSPIN AWH-M ISO 46 (55 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0884880	WC0830449	WC0753864
Sample Date	Client Info		10 Jan 2024	17 Jul 2023	04 Dec 2022
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	ABNORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	0
Chromium	ppm	ASTM D5185m	>20	0	0
Nickel	ppm	ASTM D5185m	>20	0	0
Titanium	ppm	ASTM D5185m		<1	0
Silver	ppm	ASTM D5185m		0	<1
Aluminum	ppm	ASTM D5185m	>20	2	0
Lead	ppm	ASTM D5185m	>20	0	0
Copper	ppm	ASTM D5185m	>20	<1	<1
Tin	ppm	ASTM D5185m	>20	<1	0
Vanadium	ppm	ASTM D5185m		0	0
Cadmium	ppm	ASTM D5185m		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0
Barium	ppm	ASTM D5185m		0	1
Molybdenum	ppm	ASTM D5185m		<1	0
Manganese	ppm	ASTM D5185m		0	0
Magnesium	ppm	ASTM D5185m		<1	<1
Calcium	ppm	ASTM D5185m		39	44
Phosphorus	ppm	ASTM D5185m		352	391
Zinc	ppm	ASTM D5185m		409	517
Sulfur	ppm	ASTM D5185m		1082	2293

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1
Sodium	ppm	ASTM D5185m		0	0
Potassium	ppm	ASTM D5185m	>20	1	<1
Water	%	ASTM D6304	>0.05	NEG	NEG

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	3779	3054	371
Particles >6µm	ASTM D7647	>1300	974	▲ 1363	79
Particles >14µm	ASTM D7647	>160	59	▲ 314	3
Particles >21µm	ASTM D7647	>40	15	▲ 110	1
Particles >38µm	ASTM D7647	>10	1	8	0
Particles >71µm	ASTM D7647	>3	0	1	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	19/17/13	▲ 19/18/15	16/13/9

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.31	0.40



OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.0	42.0	42.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0884880 **Recieved** : 11 Jan 2024
Lab Number : 06058049 **Diagnosed** : 12 Jan 2024
Unique Number : 10829431 **Diagnostician** : Doug Bogart
Test Package : PLANT

LUND BOATS
 318 WEST GILMAN ST
 NEW YORK MILLS, MN
 US 56567
 Contact: TODD PITMAN
 todd.pitman@lundboats.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)