

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SM 7.5 4306517 (S/N 1055)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Fluid

DIAGNOSIS ▲ Recommendation

We were unable to perform a particle count on this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the

Fluid Condition

The AN level is acceptable for this fluid.

		76:2016 00:	UIT May2UIO Jan2UIS	Jun2020 May2021 May2022	Jul2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA010110	KCPA004135	KCP55510
Sample Date		Client Info		29 Dec 2023	17 Jul 2023	09 Dec 2022
Machine Age	hrs	Client Info		37996	36068	34119
Oil Age	hrs	Client Info		0	0	1600
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	<1	0
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	11	0	9
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	66	67	55
Calcium	ppm	ASTM D5185m	2	1	0	0
Phosphorus	ppm	ASTM D5185m		11	<1	2
Zinc	ppm	ASTM D5185m		0	0	4
Sulfur	ppm	ASTM D5185m		20767	22937	21621
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		10	18	13
Potassium	ppm	ASTM D5185m	>20	2	1	<1
Water	%	ASTM D6304	>0.05	<u>0.221</u>	0.022	△ 0.153
ppm Water	ppm	ASTM D6304	>500	<u>^</u> 2210	223.0	<u></u> 1530
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			1179	42271
Particles >6µm		ASTM D7647	>1300		365	△ 6781
Particles >14µm		ASTM D7647	>80		27	▲ 364
Particles >21µm		ASTM D7647	>20		7	▲ 78
Particles >38µm		ASTM D7647	>4		1	1
Particles >71µm		ASTM D7647	>3		0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13		17/16/12	<u>\$\text{23}\20/16\$</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	I/OII/-	AOTM DOOM	0.4	0.31	N 31	U 35

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.31

0.31

0.32



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number**

: 06058086

: KCPA010110 : 10829468

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved

: 11 Jan 2024 Diagnosed : 12 Jan 2024 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Jul17/23

00.00 PG

OXMOOR CHRYSLER

4520 SHELBYVILLE RD LOUISVILLE, KY US 40207

Contact: J. MIDDLETON

T: F: