

Machine Id A (S/N N/A)

Component Vacuum Pump Fluid USPI VAC 100 (--- QTS)

Ferrous Alloys

300

250

200

<u>ل</u> 150

100

50

0

Dec29/2

COMPONENT CONDITION SUMMARY

iron chromium

nickel

Mar24/22





RECOMMENDATION

We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

Sep15/22

Jan5/23

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE	ABNORMAL	ABNORMAL		
Iron	ppm	ASTM D5185m	>20	e 278	1 35	<u> </u>		
Particles >4µm		ASTM D7647	>10000	<u> </u>	A 214957	🔺 205617		
Particles >6µm		ASTM D7647	>2500	<u> </u>	1 43667	1 41083		
Particles >14µm		ASTM D7647	>640	4 924	<u> </u>	▲ 8643		
Oil Cleanliness		ISO 4406 (c)	>20/18/16	<u> </u>	▲ 25/24/21	▲ 25/24/20		

Customer Id: KRAKIRMO Sample No.: USPM30580 Lab Number: 06058115 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Inspect Wear Source			?	We advise that you inspect for the source(s) of wear.			
Change Filter			?	We recommend you service the filters on this component.			
Resample			?	We recommend an early resample to monitor this condition.			

HISTORICAL DIAGNOSIS



15 Oct 2023 Diag: Doug Bogart

We recommend you service the filters on this component. Resample at the next service interval to monitor. The iron level is abnormal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



10 Jul 2023 Diag: Doug Bogart

fluid. The condition of the oil is suitable for further service.

WEAR

view report

04 May 2023 Diag: Doug Bogart



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

We recommend you service the filters on this component. Resample at the next service interval to monitor. The iron level is abnormal. There is a high amount of particulates present in the oil. The AN level is acceptable for this





OIL ANALYSIS REPORT

Sample Rating Trend



Dec2021 Mar2022 Sep2022 Jap2023 Mar2023 Jul2023 Oct2023 Ja

	SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
	Sample Number		Client Info		USPM30580	USPM31031	USPM27751
lters on this	Sample Date		Client Info		10 Jan 2024	15 Oct 2023	10 Jul 2023
spect for the	Machine Age	hrs	Client Info		0	0	0
d an early	Oil Age	hrs	Client Info		0	0	0
•	Oil Changed		Client Info		N/A	N/A	N/A
	Sample Status				SEVERE	ABNORMAL	ABNORMAL
	WEAR METALS		method	limit/base	current	history1	history2
ates present in	Iron	ppm	ASTM D5185m	>20	e 278	1 35	 74
	Chromium	ppm	ASTM D5185m	>20	<1	<1	0
	Nickel	ppm	ASTM D5185m	>20	<1	0	0
fluid.	Titanium	ppm	ASTM D5185m		<1	0	<1
	Silver	ppm	ASTM D5185m		0	0	0
	Aluminum	ppm	ASTM D5185m	>20	0	<1	1
	Lead	ppm	ASTM D5185m	>20	0	0	0
	Copper	ppm	ASTM D5185m	>20	<1	<1	<1
	Tin	ppm	ASTM D5185m	>20	<1	<1	<1
	Vanadium	ppm	ASTM D5185m		0	0	<1
	Cadmium	ppm	ASTM D5185m		0	0	<1
	ADDITIVES		method	limit/base	current	history1	history2
	Boron	ppm	ASTM D5185m	0	0	0	0
	Barium	ppm	ASTM D5185m	0	0	0	0
	Molybdenum	ppm	ASTM D5185m	0	<1	0	0
	Manganese	ppm	ASTM D5185m		<1	<1	<1
	Magnesium	ppm	ASTM D5185m	0	1	0	0
	Calcium	ppm	ASTM D5185m	0	3	0	2
	Phosphorus	ppm	ASTM D5185m	1800	1383	1353	1466
	Zinc	ppm	ASTM D5185m	0	0	0	0
	Sulfur	ppm	ASTM D5185m	0	0	0	2
	CONTAMINANTS	6	method	limit/base	current	history1	history2
	Silicon	ppm	ASTM D5185m	>15	16	13	2
	Sodium	ppm	ASTM D5185m		91	62	6
	Potassium	ppm	ASTM D5185m	>20	38	25	8
	Water	%	ASTM D6304	>.1	0.040	0.054	0.048
	ppm Water	ppm	ASTM D6304	>1000	410	543.8	481.7
	FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
	Particles >4µm		ASTM D7647	>10000	A 217709	2 14957	▲ 205617
	Particles >6µm		ASTM D7647	>2500	<u> </u>	<u>▲</u> 143667	1 41083
	Particles >14µm		ASTM D7647	>640	<mark>/</mark> 924	1 0391	▲ 8643
	Particles >21µm		ASTM D7647	>160	36	<u> </u>	▲ 395
	Particles >38µm		ASTM D7647	>40	1	7	2
	Particles >71µm		ASTM D7647	>10	0	0	0
	Oil Cleanliness		ISO 4406 (c)	>20/18/16	<u> </u>	▲ 25/24/21	▲ 25/24/20
	FLUID DEGRAD	ATION	method	limit/base	current	history1	history2

L7A (S/N N/A)

Vacuum Pump Fluid USPI VAC 100 (--- QTS)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

🛑 Wear

The iron level is severe.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.



OIL ANALYSIS REPORT







2000

1000

Aar74/75

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
			11 11 11		1.1.1.1.1.1.1	
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	91	109	106	103
SAMPLE IMAGES	;	method	limit/base	current	history1	history2
Color						J.

Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: Y - LARRY WISKIRCHEN - KRAKIRMO