



# OIL ANALYSIS REPORT

Sample Rating Trend

DEGRADATION



Machine Id  
**C2**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**CAMCO 717 HT (130 GAL)**

## DIAGNOSIS

### Recommendation

We advise an early resample to confirm this situation.

### Wear

The iron level is abnormal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is above the recommended limit. Confirmed. Confirm oil type.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>USP0005259</b>	---	---
Sample Date	Client Info	<b>05 Jan 2024</b>	---	---
Machine Age	hrs Client Info	<b>0</b>	---	---
Oil Age	hrs Client Info	<b>0</b>	---	---
Oil Changed	Client Info	<b>N/A</b>	---	---
Sample Status		<b>ABNORMAL</b>	---	---

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185m	>8	<b>▲ 47</b>	---	---
Chromium ppm ASTM D5185m	>2	<b>0</b>	---	---
Nickel ppm ASTM D5185m		<b>&lt;1</b>	---	---
Titanium ppm ASTM D5185m		<b>0</b>	---	---
Silver ppm ASTM D5185m	>2	<b>0</b>	---	---
Aluminum ppm ASTM D5185m	>3	<b>&lt;1</b>	---	---
Lead ppm ASTM D5185m	>2	<b>0</b>	---	---
Copper ppm ASTM D5185m	>8	<b>0</b>	---	---
Tin ppm ASTM D5185m	>4	<b>&lt;1</b>	---	---
Vanadium ppm ASTM D5185m		<b>0</b>	---	---
Cadmium ppm ASTM D5185m		<b>0</b>	---	---

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185m		<b>0</b>	---	---
Barium ppm ASTM D5185m		<b>0</b>	---	---
Molybdenum ppm ASTM D5185m		<b>0</b>	---	---
Manganese ppm ASTM D5185m		<b>0</b>	---	---
Magnesium ppm ASTM D5185m		<b>2</b>	---	---
Calcium ppm ASTM D5185m		<b>2</b>	---	---
Phosphorus ppm ASTM D5185m		<b>54</b>	---	---
Zinc ppm ASTM D5185m		<b>0</b>	---	---
Sulfur ppm ASTM D5185m		<b>248</b>	---	---

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm ASTM D5185m	>15	<b>0</b>	---	---
Sodium ppm ASTM D5185m		<b>&lt;1</b>	---	---
Potassium ppm ASTM D5185m	>20	<b>1</b>	---	---
Water % ASTM D6304	>0.01	<b>0.001</b>	---	---
ppm Water ppm ASTM D6304	>100	<b>15</b>	---	---

## FLUID CLEANLINESS





method	limit/base	current	history1	history2
Particles >4µm ASTM D7647	>10000	<b>3762</b>	---	---
Particles >6µm ASTM D7647	>2500	<b>978</b>	---	---
Particles >14µm ASTM D7647	>320	<b>73</b>	---	---
Particles >21µm ASTM D7647	>80	<b>15</b>	---	---
Particles >38µm ASTM D7647	>20	<b>1</b>	---	---
Particles >71µm ASTM D7647	>4	<b>0</b>	---	---
Oil Cleanliness ISO 4406 (c)	>20/18/15	<b>19/17/13</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g ASTM D974	0.007	<b>▲ 0.587</b>	---	---



# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.01	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	69	64.8	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

## GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : USP0005259 Recieved : 11 Jan 2024  
 Lab Number : 06058124 Diagnosed : 18 Jan 2024  
 Unique Number : 10829506 Diagnostician : Doug Bogart  
 Test Package : IND 2

**POET BIOREFINING - LAKE CRYSTAL**  
 19200 499TH AVE  
 LAKE CRYSTAL, MN  
 US 56055  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: