

OIL ANALYSIS REPORT

Area NOT GIVEN [SO-272463] Machine Id PNEUTECH PNEUTECH RK-15VSD-115B (S/N NOT GIVEN) Component

Compressor

Fluid

{not provided} (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend



NORMAL

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0000226		
Sample Date		Client Info		03 Jan 2024		
Machine Age	hrs	Client Info		10389		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		335		
Zinc	ppm	ASTM D5185m		13		
Sulfur	ppm	ASTM D5185m		19		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.08		




OIL ANALYSIS REPORT

VISUAL

Acid Number





White Metal						
	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	LIGHT		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water			>0.1	NEG		
Free water	scalar	*Visual		NEG		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		46.3		
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image
GRAPHS Ferrous Alloys						
5						
Jan 3/24			Jan3/24			
Non-ferrous Metals	S					
copper						
6 tin						
•						
2 - 						
			lan3/24			
Viscosity @ 40°C			Jan3/24	Acid Number		
Viscosity @ 40°C				Acid Number		
boommal				Acid Number		
Viscosity @ 40°C				Acid Number		
Viscosity @ 40°C				Acid Number		
Viscosity @ 40°C				Acid Number		
Viscosity @ 40°C			(5) 0.10 HOX 0.08 But 0.06 Hummer Hox 0.04 Hummer Hox 0.02 Hox 0.00			
Viscosity @ 40°C				Acid Number		P D D D D D D D D D D D D D D D D D D D
Viscosity @ 40°C			(5) 0.10 HOX 0.08 But 0.06 Hummer Hox 0.04 Hummer Hox 0.02 Hox 0.00			a C.C. Free
Viscosity @ 40°C			(0,10) HOX 0.08 Provide 10,000 Provide 1	Jan3/24		
Viscosity @ 40°C	Recieved	d :11.	ry, NC 27513 Jan 2024	Jan3/24	550	RE DYNAMICS
Viscosity @ 40°C	Recievec Diagnose	d :11. ed :14.	ry, NC 27513 Jan 2024 Jan 2024	Jan3/24	550	Re Dynamics D Albion Ave IAUMBURG, II
Viscosity @ 40°C	Recieved	d :11. ed :14.	ry, NC 27513 Jan 2024	Jan3/24	550 SCH	RE DYNAMIC: D ALBION AVI

To discuss this sample report, co * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Laboratory

Sample No. Lab Number **Unique Number Test Package**

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

F:

T: (847)678-8388