

# **OIL ANALYSIS REPORT**

Sample Rating Trend ISO

# KAESER 7971150

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Sep2022	Dec2023		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA010851	KCP50674	
Sample Date		Client Info		29 Dec 2023	07 Sep 2022	
Machine Age	hrs	Client Info		5333	1389	
Oil Age	hrs	Client Info		0	1389	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	2	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	2	2	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	41	40	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	100	84	65	
Calcium	ppm	ASTM D5185m	0	1	2	
Phosphorus	ppm	ASTM D5185m	0	20	5	
Zinc	ppm	ASTM D5185m	0	0	4	
Sulfur	ppm	ASTM D5185m	23500	22645	17010	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		17	21	
Potassium	ppm	ASTM D5185m	>20	4	2	
Water	%	ASTM D6304	>0.05	0.019	0.032	
ppm Water	ppm	ASTM D6304	>500	200	329.6	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8403		
Particles >6µm		ASTM D7647	>1300	<u>▲</u> 3188		
Particles >14μm		ASTM D7647	>80	<b>145</b>		
Particles >21µm		ASTM D7647	>20	18		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/19/14</b>		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma KO∐/a	ASTM D8045	1.0	0.34	0.31	

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.31

0.34



# **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: KCPA010851 : 06058743

: 10830125

Recieved : 11 Jan 2024 Diagnosed : 14 Jan 2024 Diagnostician : Don Baldridge

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**AMAZON.COM SERVICES LLC** 820 FEDERAL SCHOOL LN

NEW CASTLE, DE US 19720

Contact: Service Manager eldepell@amazon.com

T:

F: