

# **OIL ANALYSIS REPORT**

Sample Rating Trend

**NORMAL** 



Machine Id **8654333 (S/N 1689)** 

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			:			
			Jul2023	Jan2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC124455	KC108217	
Sample Date		Client Info		02 Jan 2024	14 Jul 2023	
Machine Age	hrs	Client Info		5191	3102	
Oil Age	hrs	Client Info		0	3102	
Oil Changed		Client Info		N/A	Changed	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	3	10	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m	7 10	0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES	1-1-		Page 21 / Page 22 / Page 2		la faction and	latata w O
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	2	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	29	1	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		20	1	
Zinc	ppm	ASTM D5185m		0	4	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	1	<1	
Water	%	ASTM D6304	>0.05	0.010	0.007	
ppm Water	ppm	ASTM D6304	>500	100	77.4	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		939	20105	
Particles >6µm		ASTM D7647	>1300	311	<u> </u>	
Particles >14µm		ASTM D7647	>80	35	▲ 306	
Particles >21µm		ASTM D7647	>20	9	10	
Particles >38µm		ASTM D7647	>4	0	1	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/12	<u>^</u> 22/21/15	
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.33

0.32



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number Unique Number Test Package

: KC124455 : 06058747 : 10830129

: IND 2

Recieved : 11 Jan 2024

Diagnosed : 14 Jan 2024 Diagnostician : Don Baldridge 9 CYPRESS RD PASS

OCALA, FL US 34472

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: