




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
135-12
 Component
Natural Gas Engine
 Fluid
NOT GIVEN (30 QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. (Customer Sample Comment: Oil and KO filters were changed @ 9596 hrs. That was the first oil change since KO install.)

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KL0012993	KL0011512	KL0011961
Sample Date	Client Info		05 Jan 2024	20 Nov 2023	16 Oct 2023
Machine Age	hrs	Client Info	10244	9202	8366
Oil Age	hrs	Client Info	648	1783	673
Oil Changed		Client Info	N/A	N/A	N/A
Sample Status			NORMAL	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	5	17	5
Chromium	ppm	ASTM D5185m >4	<1	<1	0
Nickel	ppm	ASTM D5185m >2	<1	<1	0
Titanium	ppm	ASTM D5185m	40	16	17
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >9	2	2	3
Lead	ppm	ASTM D5185m >30	8	▲ 24	5
Copper	ppm	ASTM D5185m >35	12	▲ 21	3
Tin	ppm	ASTM D5185m >4	<1	1	<1
Vanadium	ppm	ASTM D5185m	<1	<1	<1
Cadmium	ppm	ASTM D5185m	<1	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	89	25	42
Barium	ppm	ASTM D5185m	2	2	0
Molybdenum	ppm	ASTM D5185m	18	225	183
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	21	10	7
Calcium	ppm	ASTM D5185m	1481	1462	1379
Phosphorus	ppm	ASTM D5185m	407	344	320
Zinc	ppm	ASTM D5185m	402	382	380
Sulfur	ppm	ASTM D5185m	2778	3593	2740

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	4	7	5
Sodium	ppm	ASTM D5185m	0	2	1
Potassium	ppm	ASTM D5185m >20	2	2	<1

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0	0
Nitration	Abs/cm	*ASTM D7624 >20	10.8	11.4	8.4
Sulfation	Abs/.1mm	*ASTM D7415 >30	21.1	27.3	19.2



OIL ANALYSIS REPORT








FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	2949	▲ 28804	3715
Particles >6µm	ASTM D7647	>5000	1607	1258	2024
Particles >14µm	ASTM D7647	>640	273	34	344
Particles >21µm	ASTM D7647	>160	92	6	116
Particles >38µm	ASTM D7647	>40	14	1	18
Particles >71µm	ASTM D7647	>10	1	0	2
Oil Cleanliness	ISO 4406 (c)	>21/19/16	19/18/15	▲ 22/17/12	19/18/16

FLUID DEGRADATION	method	limit/base	current	history1	history2	
Oxidation	Abs./1mm	*ASTM D7414	>25	24.6	33.9	19.4
Acid Number (AN)	mg KOH/g	ASTM D8045	1.22	▲ 2.98	1.32	
Base Number (BN)	mg KOH/g	ASTM D2896	5.18	▲ 2.04	4.08	

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.2	14.7	14.5

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KL0012993 **Received** : 11 Jan 2024
Lab Number : 06058837 **Diagnosed** : 15 Jan 2024
Unique Number : 10830219 **Diagnostician** : Jonathan Hester
Test Package : MOB 2 (Additional Tests: PrtCount)

BASELINE ENERGY SOLUTIONS
 1863 2ND AVE
 GREENLEY, CO
 US 80631
 Contact: CARLOS PUENTES

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (720)670-1616
F: