




OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
KAESER SM 7.5 6110425 (S/N 1007)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

▲ Recommendation

The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

There is a light concentration of water present in the oil. Light concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KCPA011739	KCP50598	KCP39422
Sample Date	Client Info	02 Jan 2024	15 Aug 2022	05 Oct 2021
Machine Age	hrs	31828	20929	18250
Oil Age	hrs	0	2679	3000
Oil Changed	Client Info	N/A	Changed	Changed
Sample Status		ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<1	2	40
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m >3	0	0	0
Titanium	ppm	ASTM D5185m >3	0	0	<1
Silver	ppm	ASTM D5185m >2	0	0	<1
Aluminum	ppm	ASTM D5185m >10	0	4	▲ 36
Lead	ppm	ASTM D5185m >10	0	0	<1
Copper	ppm	ASTM D5185m >50	9	15	25
Tin	ppm	ASTM D5185m >10	0	<1	<1
Antimony	ppm	ASTM D5185m	---	---	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	0	0	3
Barium	ppm	ASTM D5185m 90	0	11	14
Molybdenum	ppm	ASTM D5185m 0	0	<1	2
Manganese	ppm	ASTM D5185m	0	<1	1
Magnesium	ppm	ASTM D5185m 100	0	22	43
Calcium	ppm	ASTM D5185m 0	0	0	72
Phosphorus	ppm	ASTM D5185m 0	0	22	356
Zinc	ppm	ASTM D5185m 0	0	39	570
Sulfur	ppm	ASTM D5185m 23500	14750	17355	1746

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	0	5	● 80
Sodium	ppm	ASTM D5185m	<1	9	40
Potassium	ppm	ASTM D5185m >20	0	0	8
Water	%	ASTM D6304 >0.05	▲ 0.212	0.012	▲ 0.275
ppm Water	ppm	ASTM D6304 >500	▲ 2120	123.2	▲ 2754.7




FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	---	101075	---
Particles >6µm	ASTM D7647 >1300	---	▲ 29301	---
Particles >14µm	ASTM D7647 >80	---	▲ 1309	---
Particles >21µm	ASTM D7647 >20	---	▲ 206	---
Particles >38µm	ASTM D7647 >4	---	▲ 5	---
Particles >71µm	ASTM D7647 >3	---	1	---
Oil Cleanliness	ISO 4406 (c) >--/17/13	---	▲ 24/22/18	---

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.39	0.43	1.404


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	MODER	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	50.7	51.1	▲ 74.47

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA011739 **Recieved** : 12 Jan 2024
Lab Number : 06059301 **Diagnosed** : 16 Jan 2024
Unique Number : 10830683 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PrtCount)

GRACON CONSTRUCTION INC
 1513 CRENSHAW RD
 ROYSE CITY, TX
 US 75189
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: