

## **OIL ANALYSIS REPORT**

## IR ULTRA COOLANT [1398035] Machine Id INGERSOLL RAND F6639U96120 - BACK-UP UNIT Component

Compressor

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend



NORMAL


SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06059380		
Sample Date		Client Info		15 Nov 2023		
Machine Age	hrs	Client Info		54085		
Oil Age	hrs	Client Info		2215		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		2		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		<1		
Aluminum	ppm	ASTM D5185m	>25	1		
Lead	ppm	ASTM D5185m	>25	2		
Copper	ppm	ASTM D5185m	>50	3		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	500	740		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		1		
Magnesium	ppm	ASTM D5185m	0	4		
Calcium	ppm	ASTM D5185m	0	11		
Phosphorus	ppm	ASTM D5185m	20	3		
Zinc	ppm	ASTM D5185m	0	0		
Sulfur	ppm	ASTM D5185m	200	339		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4		
Sodium	ppm	ASTM D5185m		12		
Potassium	ppm	ASTM D5185m	>20	3		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.081		



Nov15/23

# **OIL ANALYSIS REPORT**

VISUAL



							, , , , , , , , , , , , , , , , , , ,
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Nov15/23	Appearance	scalar	*Visual	NORML	NORML		
Nov	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPERT	LIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	49.4	53.0		
	SAMPLE IMAGE		method	limit/base	current	history1	history2
		0	motriou				motory
Nov15/23 +	Color					no image	no image
	Bottom					no image	no image
	Non-ferrous Metal						
	Viscosity @ 40°C			(0,1250) (0,100 K0H) (0,100 K0	Acid Number		
	45 - Eccere 40 - ECZ 51 APN			Nov15/23	Nov15/23		
Laboratory Sample No. Lab Number	: WearCheck USA - { : UCH06059380 : 06059380	Jan 2024 Jan 2024	2024 1055 CLUSTER D				

Contact/Location: KEVIN PLISKA - UCAIRTOL