




# OIL ANALYSIS REPORT

Sample Rating Trend

DEGRADATION



Area  
**ROTO EXTEND**  
 Machine Id  
**ATLAS COPCO API623627 - PLASTIC OMNIUM P/A**  
 Component  
**Compressor**



## DIAGNOSIS

### ▲ Recommendation

The oil is near the end of its useful service life, recommend schedule an oil change. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### ▲ Fluid Condition

The AN level is at the top-end of the recommended limit.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>UCH06059382</b>	UCH04249500	---
Sample Date	Client Info		<b>01 Dec 2023</b>	25 Jun 2017	---
Machine Age	hrs	Client Info	<b>30378</b>	4220	---
Oil Age	hrs	Client Info	<b>6609</b>	4220	---
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	---
Sample Status			<b>ATTENTION</b>	NORMAL	---

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	NEG	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	<1	---
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	---
Nickel	ppm	ASTM D5185m	<b>2</b>	0	---
Titanium	ppm	ASTM D5185m	<b>0</b>	0	---
Silver	ppm	ASTM D5185m	<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m >25	<b>1</b>	0	---
Lead	ppm	ASTM D5185m >25	<b>3</b>	3	---
Copper	ppm	ASTM D5185m >50	<b>19</b>	<1	---
Tin	ppm	ASTM D5185m >15	<b>0</b>	<1	---
Antimony	ppm	ASTM D5185m	<b>---</b>	0	---
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	---
Barium	ppm	ASTM D5185m	<b>6</b>	0	---
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	---
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Calcium	ppm	ASTM D5185m	<b>&lt;1</b>	0	---
Phosphorus	ppm	ASTM D5185m	<b>2</b>	4	---
Zinc	ppm	ASTM D5185m	<b>&lt;1</b>	19	---
Sulfur	ppm	ASTM D5185m	<b>1</b>	0	---

## CONTAMINANTS



	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>&lt;1</b>	0	---
Sodium	ppm	ASTM D5185m	<b>0</b>	1	---
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	2	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.14	<b>▲ 1.40</b>	0.608	---




# OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	51.0	47.77	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : UCH06059382 **Received** : 12 Jan 2024  
**Lab Number** : 06059382 **Diagnosed** : 16 Jan 2024  
**Unique Number** : 10830764 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2

**AIR TECHNOLOGIES INC (DET-LIV)**  
 11771 BELDEN CT  
 LIVONIA, MI  
 US 48150-1446  
 Contact: MICHAEL WYSZCZELSKI  
 michael.wyszczelski@otcindustrial.com  
 T: (734)762-9247  
 F: (734)762-9248

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)