

OIL ANALYSIS REPORT

Sample Rating Trend

DEGRADATION



Machine Id WVTM02BE Component

Biogas Engine

CHEVRON HDAX 6500 LFG GAS ENGINE OIL (--- GAL)

GAS ENGINE OIL (GAL)										
SAMPLE INFOR	MATION	method	limit/base	current	history1	history				
Sample Number		Client Info		WC0785358	WC0785356	WC062943				
Sample Date		Client Info		09 Jan 2024	08 Jan 2024	03 Jan 202				
Machine Age	hrs	Client Info		42764	42675	42602				
Dil Age	hrs	Client Info		595	506	433				
Dil Changed		Client Info		Not Changd	Not Changd	Not Change				
Sample Status				ABNORMAL	NORMAL	NORMAL				
CONTAMINATIC	N	method	limit/base	current	history1	history				
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0				
Nater		WC Method	>0.1	NEG	NEG	NEG				
Glycol		WC Method		NEG	NEG	NEG				
WEAR METALS		method	limit/base	current	history1	history				
ron	ppm	ASTM D5185m	>15	0	2	2				
Chromium	ppm	ASTM D5185m	>4	<1	0	0				
Nickel	ppm	ASTM D5185m	>2	1	0	0				
Titanium	ppm	ASTM D5185m		0	0	0				
Silver	ppm	ASTM D5185m	>5	0	0	0				
Aluminum	ppm	ASTM D5185m	>6	2	1	<1				
_ead	ppm	ASTM D5185m	>9	3	2	2				
Copper	ppm	ASTM D5185m	>6	1	<1	<1				
Γin	ppm	ASTM D5185m	>4	2	2	2				
/anadium	ppm	ASTM D5185m		0	<1	0				
Cadmium	ppm	ASTM D5185m		0	0	0				
ADDITIVES		method	limit/base	current	history1	history				
Boron	ppm	ASTM D5185m		0	<1	0				
Barium	ppm	ASTM D5185m		0	0	0				
Nolybdenum	ppm	ASTM D5185m		0	<1	0				
Manganese	ppm	ASTM D5185m		<1	<1	0				
Magnesium	ppm	ASTM D5185m		9	7	6				
Calcium	ppm	ASTM D5185m		1782	1772	1783				
Phosphorus	ppm	ASTM D5185m		267	280	258				
Zinc	ppm	ASTM D5185m		341	324	324				
Sulfur	ppm	ASTM D5185m		3858	3271	3053				
CONTAMINANT	S	method	limit/base	current	history1	history				
Silicon	ppm	ASTM D5185m	>181	111	94	79				
Sodium	ppm	ASTM D5185m		0	<1	0				
Potassium	ppm	ASTM D5185m	>20	0	<1	0				
INFRA-RED		method	limit/base	current	history1	history				
Soot %	%	*ASTM D7844		0	0	0				
Nitration	Abs/cm	*ASTM D7624	>20	4.9	5.0	5.1				
Sulfation	Abs/.1mm	*ASTM D7415	>30	26.0	24.0	21.5				
FLUID DEGRAD	ATION	method	limit/base	current	history1	history				
Dxidation	Abs/.1mm	*ASTM D7414	>25	14.7	13.3	11.4				
Acid Number (AN)	mg KOH/g	ASTM D8045	1.2	<u> </u>	1.69	1.89				
Base Number (BN)	ma KOH/a	ASTM D2896	4.5	1.67	1.84	2.63				

DIAGNOSIS

Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. (Customer Sample Comment: Oil sample only)

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN level is low. The AN level is at the top-end of the recommended limit.



OIL ANALYSIS REPORT





	VISUAL		method	limit/base	current	history1	history2
Λ	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
11	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
INN	Precipitate		*Visual	NONE	NONE	NONE	NONE
-VV	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
6/23	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Dec2	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
	Free Water	scalar	*Visual		NEG	NEG	NEG
	FLUID PROPERT	TIES	method	limit/base	current	history1	history2
Λ	Visc @ 100°C	cSt	ASTM D445	14.7	13.7	13.4	13.6
12	GRAPHS						
1	Iron (ppm)				Lead (ppm)		
	40			15	Severe		
c26/2.	30		٨	10	Abnormal		
De	E 20 Abnormal		/1-	bhu	P		
	10-		/1	5		An	M
	mm	m	NL	-		WVV	~ V
	4/23 5/23 5/23	3/23 -	4/23 - 1/23 -	U	\$/23 8/23	4/23 5/23	3/23
	Mar24 Mayê Jun5 Jul24	Sept	Oct24 Nov30		Mar2 ⁴ Mayê Jun5	Jul24 Sep6 Oct24	Nov3(Dec26
•	Aluminum (ppm)				Chromium (pr	om)	
1-	12 Severe		1000000000000	6	Severe		
	10-			5	Abnormal		
	E 6 Abnormal			4 E.3	I		
c26/2	4-	~		2			
De		11	~~~~				
		23+	23 - 23 - 23 - 23 - 23 - 23 - 23 - 23 -	0	23	23 23	23
	flar24/ May8/ Jun5//	Sep6/.)ct24/ 'ov30/,		Nar24/ Nay8// Jun5//	Jul24// Sep6//	lov30/.
	≥ = · · · ·	1997 B.			Silicon (nnm)		2 0
			170000500000	250	Jincon (ppin)		noonpooratana
	15 Severe			200	Severe Abnormal		- 1-
	E			_₽ 150		MAA	NI
	Abnormal			^눮 100	M/V/	VVVN	
	5- 9			50	IV V		V
				- 0	L		
	r24/2: ay8/23 n5/23 [24/23	sp6/23	124/2: 130/23		r24/2: ay8/23 m5/23	124/2: p6/23 24/23	/30/2:
	Mai Mi Ju Uu	Se	Nov		Ma Mi	Se	Nov
	Viscosity @ 100°C	2			Base Number		
	Abnormal		11211	6.0 £50	Rana A		
	De Base			94.0	X /	A	
		~~		<u>له</u> ع		MAN	nl
	Abrormal				Y	VU	V V V
	10			<u>الم</u>			- W
	\$/23 3/23 5/23	3/23	4/23 - 3/23 -	0.0	\$/23 3/23 5/23	4/23 - 5/23 -)/23 - 3/23 -
	5 Q S	b	:t2 ⁴ v30		ay8 an5	124 ep6 t24	v3(c26
	Mar2 Jur Jul2	ŝ	No of		Na Na	Ju Ss	De No
	Marû Jur	Š	No Oc		Ma M	Ju Ss Oc	No



Test Package : MOB 2 Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician : Don Baldridge

Unique Number : 10830800

scott.eastman@edlenergy.com

Contact: Scott Eastman

US 49098

T:

F: