KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Machine Id
KAESER 6970126 (S/N 1040)
Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

▲ Recommendation
No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

▲ Contamination
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**KC123274**	KCPA003528	KC105948
Sample Date		Client Info		**05 Jan 2024**	22 Aug 2023	01 Feb 2023
Machine Age	hrs	Client Info		**12712**	11465	9092
Oil Age	hrs	Client Info		**0**	0	4395
Oil Changed		Client Info		**N/A**	N/A	Not Changd
Sample Status				**ATTENTION**	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	**0**	<1	<1
Chromium	ppm	ASTM D5185m	>10	**<1**	0	0
Nickel	ppm	ASTM D5185m	>3	**0**	0	0
Titanium	ppm	ASTM D5185m	>3	**0**	<1	0
Silver	ppm	ASTM D5185m	>2	**0**	0	0
Aluminum	ppm	ASTM D5185m	>10	**2**	0	1
Lead	ppm	ASTM D5185m	>10	**0**	0	0
Copper	ppm	ASTM D5185m	>50	**28**	30	12
Tin	ppm	ASTM D5185m	>10	**0**	0	0
Antimony	ppm	ASTM D5185m		**---**	---	---
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	**0**	0	0
Barium	ppm	ASTM D5185m	90	**0**	0	0
Molybdenum	ppm	ASTM D5185m	0	**0**	0	0
Manganese	ppm	ASTM D5185m		**0**	0	<1
Magnesium	ppm	ASTM D5185m	100	**0**	0	13
Calcium	ppm	ASTM D5185m	0	**0**	0	<1
Phosphorus	ppm	ASTM D5185m	0	**35**	2	8
Zinc	ppm	ASTM D5185m	0	**0**	0	31

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**2**	2	2
Sodium	ppm	ASTM D5185m		**<1**	<1	1
Potassium	ppm	ASTM D5185m	>20	**<1**	0	0
Water	%	ASTM D6304	>0.05	**0.008**	▲ 0.135	▲ 0.365
ppm Water	ppm	ASTM D6304	>500	**87**	▲ 1350	▲ 3650

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		**6960**	7308	6925
Particles >6µm		ASTM D7647	>1300	▲ **1581**	▲ 3981	▲ 3772
Particles >14µm		ASTM D7647	>80	**54**	▲ 678	▲ 642
Particles >21µm		ASTM D7647	>20	**16**	▲ 228	▲ 216
Particles >38µm		ASTM D7647	>4	**0**	▲ 35	▲ 33
Particles >71µm		ASTM D7647	>3	**0**	▲ 4	▲ 3
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ **20/18/13**	▲ 20/19/17	▲ 20/19/17

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	**0.26**	0.28	0.31

KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Particle Trend



Water (KF)



Acid Number



Water (KF)



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	▲ HAZY
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	**NEG**	▲ 0.2%	▲ 0.2%
Free Water	scalar	*Visual		**NEG**	NEG	▲ 1.0

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	**47.2**	46.6	46.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC123274
Lab Number : 06060278
Unique Number : 10831660
Test Package : IND 2

Recieved : 12 Jan 2024
Diagnosed : 16 Jan 2024
Diagnostician : Doug Bogart

BELLE TIRE
2120 S LIBERTY DR
BLOOMINGTON, IN
US
Contact: Service Manager

T:
F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)