

# **OIL ANALYSIS REPORT**

## Sample Rating Trend



# KAESER AIRCENTER SM 10 6163597 (S/N 1045)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan2019 Jan2	019 Nov2019 May2020	Jan 2021 Jul 2021 Feb 2022 Jan 20	23 Dec2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC127389	KC101999	KC104416
Sample Date		Client Info		28 Dec 2023	27 Jan 2023	22 Feb 2022
Machine Age	hrs	Client Info		20614	18500	14242
Oil Age	hrs	Client Info		0	2877	2070
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ATTENTION	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	historv1	historv2

WEAR METALS		method	ilmit/base		nistory i	nistory∠
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	9	7	5
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES		method			history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	9	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	46	38	43
Calcium	ppm	ASTM D5185m	2	<1	1	0
Phosphorus	ppm	ASTM D5185m		38	2	4
Zinc	ppm	ASTM D5185m		0	6	0

CONTAMINANTS		method				history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		6	8	20
Potassium	ppm	ASTM D5185m	>20	11	2	2
Water	%	ASTM D6304	>0.05	0.016	0.016	0.013
ppm Water	ppm	ASTM D6304	>500	164	160.0	130.3


FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		2976	7595	1816
Particles >6µm	ASTM D7647	>1300	894	<b>1870</b>	422
Particles >14µm	ASTM D7647	>80	<b>A</b> 87	<b>154</b>	30
Particles >21µm	ASTM D7647	>20	<b>33</b>	▲ 38	9
Particles >38μm	ASTM D7647	>4	2	2	0
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>19/17/14</b>	▲ 20/18/14	16/12

mg KOH/g ASTM D8045 0.4 0.31 0.29 Acid Number (AN) 0.25

Contact/Location: STAN ? - ACCTOL



## **OIL ANALYSIS REPORT**



Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Contact: STAN

stan@accu-rite.com