

PROBLEM SUMMARY

Sample Rating Trend

WATER

CR-4401

Component

Diesel Fuel

{not provided} (--- GAL)

COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

PROBLEMATIC TEST RESULTS

This is a baseline read-out on the submitted sample. We advise that you follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted.

Sample Status

SEVERE

ABNORMAL ABNORMAL

Customer Id: BUCWILTX Sample No.: WC0867447 Lab Number: 06060482 Test Package: CONST

To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component.

HISTORICAL DIAGNOSIS

30 Sep 2023 Diag: Jonathan Hester

VIS DEBRIS



This is a baseline read-out on the submitted sample. We recommend you service the filters on this component.All metal levels are normal indicating no corrosion in the system. Moderate concentration of visible dirt/debris present in the fuel. The water content is negligible. The condition of the fuel is acceptable for the time in service.



01 Aug 2023 Diag: Jonathan Hester

WATER



We advise that you follow the water drain-off procedure for this component. We recommend you service and check the fuel filters for mucous-like deposits. Check with fuel supplier for biocides available to destroy the microorganisms in the fuel system. All metal levels are normal indicating no corrosion in the system. Moderate concentration of visible dirt/debris present in the fuel. Free water present. Appearance indicates possible bacteria or fungus (yeast and/or mold) present in the sample. {not applicable}

view report

15 Jun 2023 Diag: Jonathan Hester

NORMAL




This is a baseline read-out on the submitted sample. All metal levels are normal indicating no corrosion in the system. The water content is negligible. There is no indication of any contamination in the fuel. The condition of the fuel is acceptable for the time in service.





FUEL REPORT

Sample Rating Trend





CR-4401

Diesel Fuel

{not provided} (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample. We advise that you follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

Excessive free water present. Moderate concentration of visible dirt/debris present in the fuel. There is a moderate amount of visible silt present in the sample.


Fuel Condition


The condition of the fuel is acceptable for the time in service.

		Aprzuzz J	un2022 Aug2022 Oct20	22 Jun2023 Aug2023 Sep2023	3 Dec2023	
SAMPLE INFORM	NOITAN	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0867447	WC0833276	WC0833406
Sample Date		Client Info		04 Dec 2023	30 Sep 2023	01 Aug 2023
Machine Age	hrs	Client Info		1389	13624	1335
Sample Status				SEVERE	ABNORMAL	ABNORMAL
PHYSICAL PROP	PERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		2.66	2.74	2.85
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		39	4	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1	0	0
Sodium	ppm	ASTM D5185m	< 0.1	<1	<1	0
Potassium	ppm	ASTM D5185m	<0.1	0	0	0
Water	%	ASTM D6304	< 0.05	0.009	0.004	0.007
ppm Water	ppm	ASTM D6304	<500	89	46.2	79.0
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	0	0
Nickel	ppm	ASTM D5185m	< 0.1	0	0	0
Lead	ppm	ASTM D5185m	< 0.1	0	0	<1
Vanadium	ppm	ASTM D5185m	< 0.1	<1	0	0
Iron	ppm	ASTM D5185m	< 0.1	<1	0	<1
Calcium	ppm	ASTM D5185m	< 0.1	<1	2	<1
Magnesium	ppm	ASTM D5185m	< 0.1	0	0	<1
Phosphorus	ppm	ASTM D5185m	< 0.1	4	0	<1
Zinc	ppm	ASTM D5185m	< 0.1	<1	0	0
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color						
Bottom						




FUEL REPORT





GRAPHS





Laboratory Sample No. Lab Number Unique Number : 10831864

: WC0867447 : 06060482

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Recieved Diagnosed

: 12 Jan 2024 : 18 Jan 2024 Diagnostician : Jonathan Hester

BUCKNER - WILLIS 18123 HWY 75 NORTH WILLIS, TX US 77378 Contact: JOHN HAWKINS

Test Package : CONST (Additional Tests: Bacteria, KF) To discuss this sample report, contact Customer Service at 1-800-237-1369.

johnh@bucknercompanies.com T:

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: