


# **COOLANT REPORT**







### **DIAGNOSIS**

#### Recommendation

We recommend drain/flush system, and refill with 50/50 antifreeze water mixture.

#### Contaminants

Sediment present.


#### **Coolant Condition**

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0870574	WC0870571	WC0870505
Sample Date		Client Info		10 Jan 2024	10 Jan 2024	25 Oct 2023
Machine Age	hrs	Client Info		24666	0	23697
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		1.054	1.048	1.055
рН	Scale 0-14	ASTM D1287		7.83	8.15	8.37
Nitrites	ppm	AP-053:2009		560	560	524
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		40.0	35.8	40.7
Freezing Point	°F	ASTM D3321		-13	-3	-13
Total Dissolved Solids				234.5	275.0	213.5
Carboxylate				n/a	n/a	fail
VISUAL		method	limit/base	current	history1	history2
Coolant Color		*Visual		Pink	Pink	Pink
Coolant Appearance		*Visual	Clear	sediment	normal	sediment
Color						
Bottom						



## **COOLANT REPORT**





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: WC0870574 : 06060536

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved Diagnosed : 10831918

: 12 Jan 2024 : 17 Jan 2024 Diagnostician : Jonathan Hester

Test Package : COOL- (Additional Tests: COOL, TAN Man, TBN) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**OAK GROVE KS** 1150 E 700TH AVE ARCADIA, KS

US 66711 Contact: KALEB WEAVER

kaleb.weaver@cubedistrictenergy.com T:

F: