

# **OIL ANALYSIS REPORT**



# KAESER SFC 22S 5531808 (S/N 1619)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Samp	le Rating Trend		ISO		
method	limit/base	current	history1	history2	

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA009153		
Sample Date		Client Info		11 Dec 2023		
Machine Age	hrs	Client Info		40224		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	0		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	5		
Tin	ppm	ASTM D5185m	>10	1		
Vanadium	ppm	ASTM D5185m	7.0	<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	90	2		
Calcium	ppm	ASTM D5185m	2	0		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		15704		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m	720	2		
Potassium	ppm	ASTM D5185m	>20	0		
Water	%	ASTM D5103111	>0.05	0.008		
ppm Water	ppm	ASTM D6304	>50.03	85		
FLUID CLEANLIN		method	limit/base	current	history1	history2
		ASTM D7647	mmubase			
Particles >4µm Particles >6µm		ASTM D7647	>1300	13038 <u> 3554</u>		
•		ASTM D7647 ASTM D7647				
Particles >14μm Particles >21μm			>80 >20	▲ 193 ▲ 26		
		ASTM D7647		<b>▲</b> 36		
Particles >38µm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3			
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>21/19/15</u>		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39		



## **OIL ANALYSIS REPORT**







Lab Number **Unique Number** 

: 06061116

Diagnosed

Diagnostician : Doug Bogart

: 10832498 Test Package : IND 2 ( Additional Tests: KF, PrtCount )

Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) IRVINE, CA US 92612

Contact: Service Manager

T:

Contact/Location: Service Manager - STRIRV

F: