

# **OIL ANALYSIS REPORT**

### Sample Rating Trend



2146-C-3 N FES 1000 (S/N XA0221)

**Refrigeration Compressor** 

USPI 1009-68 SC (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| g2011 April013 April015 Janil017 Feb2019 Junil010 Sep2021 Dec2022 |          |              |            |             |             |             |
|---|----------|--------------|------------|-------------|-------------|-------------|
| SAMPLE INFORM   | MATION   | method       | limit/base | current     | history1    | history2    |
| Sample Number   |          | Client Info  |            | USP0005012  | USP0002037  | USP250697   |
| Sample Date   |          | Client Info  |            | 01 Dec 2023 | 05 Sep 2023 | 13 Jun 2023 |
| Machine Age   | hrs      | Client Info  |            | 0           | 0           | 0           |
| Oil Age   | hrs      | Client Info  |            | 0           | 0           | 0           |
| Oil Changed   |          | Client Info  |            | N/A         | N/A         | N/A         |
| Sample Status   |          |              |            | NORMAL      | NORMAL      | NORMAL      |
| WEAR METALS   |          | method       | limit/base | current     | history1    | history2    |
| Iron  | ppm      | ASTM D5185m  | >8         | 0           | 0           | 0           |
| Chromium  | ppm      | ASTM D5185m  | >2         | <1          | <1          | 0           |
| Nickel  | ppm      | ASTM D5185m  |            | 0           | 0           | 0           |
| Titanium  | ppm      | ASTM D5185m  |            | 0           | <1          | 0           |
| Silver  | ppm      | ASTM D5185m  | >2         | 0           | 0           | 0           |
| Aluminum  | ppm      | ASTM D5185m  | >3         | 0           | <1          | 0           |
| Lead  | ppm      | ASTM D5185m  | >2         | 0           | 0           | 0           |
| Copper  | ppm      | ASTM D5185m  | >8         | 0           | 0           | 0           |
| Tin   | ppm      | ASTM D5185m  | >4         | 0           | <1          | 0           |
| Vanadium  | ppm      | ASTM D5185m  |            | 0           | <1          | 0           |
| Cadmium   | ppm      | ASTM D5185m  |            | 0           | <1          | 0           |
| ADDITIVES   |          | method       | limit/base | current     | history1    | history2    |
| Boron   | ppm      | ASTM D5185m  |            | 0           | 0           | 0           |
| Barium  | ppm      | ASTM D5185m  |            | 0           | 0           | 0           |
| Molybdenum  | ppm      | ASTM D5185m  |            | 0           | 0           | 0           |
| Manganese   | ppm      | ASTM D5185m  |            | 0           | <1          | 0           |
| Magnesium   | ppm      | ASTM D5185m  |            | 0           | 0           | 0           |
| Calcium   | ppm      | ASTM D5185m  |            | 0           | 0           | 0           |
| Phosphorus  | ppm      | ASTM D5185m  |            | 0           | 0           | 0           |
| Zinc  | ppm      | ASTM D5185m  |            | 0           | 0           | 0           |
| Sulfur  | ppm      | ASTM D5185m  | 50         | 0           | 0           | 0           |
| CONTAMINANTS  |          | method       | limit/base | current     | history1    | history2    |
| Silicon   | ppm      | ASTM D5185m  | >15        | 0           | <1          | 0           |
| Sodium  | ppm      | ASTM D5185m  |            | 0           | 1           | 0           |
| Potassium   | ppm      | ASTM D5185m  | >20        | <1          | 3           | <1          |
| Water   | %        | ASTM D6304   | >0.01      | 0.006       | 0.002       | 0.004       |
| ppm Water   | ppm      | ASTM D6304   | >100       | 68          | 17.3        | 44.1        |
| FLUID CLEANLIN  | ESS      | method       | limit/base | current     | history1    | history2    |
| Particles >4µm  |          | ASTM D7647   | >10000     | 7553        | 5846        | 2927        |
| Particles >6µm  |          | ASTM D7647   |            | 1671        | 1147        | 935         |
| Particles >14µm   |          | ASTM D7647   | >320       | 44          | 30          | 32          |
| Particles >21µm   |          | ASTM D7647   |            | 7           | 6           | 6           |
| Particles >38µm   |          | ASTM D7647   | >20        | 0           | 0           | 0           |
| Particles >71µm   |          | ASTM D7647   |            | 0           | 0           | 0           |
| Oil Cleanliness   |          | ISO 4406 (c) | >20/18/15  | 20/18/13    | 20/17/12    | 19/17/12    |
| FLUID DEGRADA   | TION     | method       | limit/base | current     | history1    | history2    |
| Acid Number (AN)  | mg KOH/g | ASTM D974    | 0.005      | 0.014       | 0.014       | 0.015       |



## OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number

**Unique Number** Test Package : IND 2

: USP0005012 Recieved : 16 Jan 2024 : 06061173 : 17 Jan 2024 Diagnosed : 10832555 Diagnostician

: Doug Bogart

800 INDUSTRIAL ROAD DENISON, IA

US 51442 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) T: (712)263-7414

F: (712)263-7314