

PROBLEM SUMMARY


Sample Rating Trend

WEAR

MYCOM TYSNRH HS315 (S/N 2535318)


Refrigeration Compressor


USPI 1009-68 SC (--- GAL)







COMPONENT CONDITION SUMMARY









RECOMMENDATION

We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS										
Sample Status				SEVERE	ABNORMAL	NORMAL				
Iron	ppm	ASTM D5185m	>8	<u>^</u> 6	0	0				
Aluminum	ppm	ASTM D5185m	>3	72	<u>\$\times\$</u> 25	<1				
Water	%	ASTM D6304	>0.01	△ 0.019	0.011	0.007				
ppm Water	ppm	ASTM D6304	>100	192	115.5	73.5				
Particles >6μm		ASTM D7647	>2500	44713	325	2366				
Particles >14μm		ASTM D7647	>320	2763	16	42				
Particles >21µm		ASTM D7647	>80	^ 764	3	6				
Particles >38µm		ASTM D7647	>20	4 1	0	0				
Oil Cleanliness		ISO 4406 (c)	>/18/15	<u>^</u> 25/23/19	18/16/11	20/18/13				

Customer Id: TYSNORTX Sample No.: USP0004989 Lab Number: 06061196 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

Action Status Date Done By Description Inspect Wear Source --- ? We advise that you inspect for the source(s) of wear. Change Filter --- ? We recommend you service the filters on this component. Resample --- ? We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

11 Jul 2023 Diag: Doug Bogart

WEAR



Resample at the next service interval to monitor. An increase in the aluminum level is noted. Confirmed. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



13 Apr 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

12 Feb 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

MYCOM TYSNRH HS315 (S/N 2535318)

Component

Refrigeration Compressor

USPI 1009-68 SC (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

Wear

Aluminum ppm levels are severe. Iron ppm levels are marginal.

Contamination

There is a high amount of particulates present in the oil. There is a trace of moisture present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

-2012 Ont2013 Aug2015 Sep-2017 Feb:2019 Apz2020 Jul2021 Ont2022									
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2			
Sample Number		Client Info		USP0004989	USP255398	USP248648			
Sample Date		Client Info		15 Jan 2024	11 Jul 2023	13 Apr 2023			
Machine Age	hrs	Client Info		0	0	0			
Oil Age	hrs	Client Info		0	0	0			
Oil Changed		Client Info		N/A	N/A	N/A			
Sample Status				SEVERE	ABNORMAL	NORMAL			
WEAR METALS		method	limit/base	current	history1	history2			
Iron	ppm	ASTM D5185m	>8	<u>^</u> 6	0	0			
Chromium	ppm	ASTM D5185m	>2	<1	0	0			
Nickel	ppm	ASTM D5185m		0	0	0			
Titanium	ppm	ASTM D5185m		0	0	0			
Silver	ppm	ASTM D5185m	>2	0	0	0			
Aluminum	ppm	ASTM D5185m	>3	1 72	<u>^</u> 25	<1			
Lead	ppm	ASTM D5185m	>2	0	0	0			
Copper	ppm	ASTM D5185m	>8	<1	0	0			
Tin	ppm	ASTM D5185m	>4	0	0	0			
Vanadium	ppm	ASTM D5185m		0	<1	0			
Cadmium	ppm	ASTM D5185m		0	0	0			
ADDITIVES		method	limit/base	current	history1	history2			
Boron	ppm	ASTM D5185m		0	0	0			
Barium	ppm	ASTM D5185m		0	0	0			
Molybdenum	ppm	ASTM D5185m		0	0	0			
Manganese	ppm	ASTM D5185m		0	0	<1			
Magnesium	ppm	ASTM D5185m		0	0	0			
Calcium	ppm	ASTM D5185m		0	0	0			
Phosphorus	ppm	ASTM D5185m		0	<1	0			
Zinc	ppm	ASTM D5185m		2	3	0			
Sulfur	ppm	ASTM D5185m	50	0	10	0			
CONTAMINANTS	;	method	limit/base	current	history1	history2			
Silicon	ppm	ASTM D5185m	>15	2	<1	0			
Sodium	ppm	ASTM D5185m		<1	0	0			
Potassium	ppm	ASTM D5185m	>20	<1	0	0			
Water	%	ASTM D6304	>0.01	△ 0.019	0.011	0.007			
ppm Water	ppm	ASTM D6304	>100	192	115.5	73.5			
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2			
Particles >4µm		ASTM D7647		163024	1500	9776			
Particles >6µm		ASTM D7647	>2500	44713	325	2366			
- Particles >14μm		ASTM D7647	>320	2763	16	42			
Particles >21µm		ASTM D7647	>80	^ 764	3	6			
Particles >38µm		ASTM D7647	>20	<u></u> 41	0	0			
Particles >71µm		ASTM D7647	>4	3	0	0			
Oil Cleanliness		ISO 4406 (c)	>/18/15	<u>^</u> 25/23/19	18/16/11	20/18/13			
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2			

Acid Number (AN)

mg KOH/g ASTM D974 0.005


0.014

0.014

0.014



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: 06061196 : 10832578 Test Package : IND 2

: USP0004989 Recieved : 16 Jan 2024

Diagnosed : 18 Jan 2024 Diagnostician : Doug Bogart

6350 BLOWN CT NORTH RICHLAND HILLS, TX

US 76180 Contact: JOHN MORGAN

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)