

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

SULLAIR 003-86959 - LEGGETT AND PLATT

Compressor Fluid

COMPRESSOR OIL (PAG) ISO 46 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0886218		
Sample Date		Client Info		02 Jan 2024		
Machine Age	hrs	Client Info		1680		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.8	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	2		
Barium	ppm	ASTM D5185m	525	359		
Molybdenum	ppm	ASTM D5185m	10	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	5	0		
Calcium	ppm	ASTM D5185m	10	1		
Phosphorus	ppm	ASTM D5185m	250	36		
Zinc	ppm	ASTM D5185m	100	0		
Sulfur	ppm	ASTM D5185m	400	499		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		73		
Potassium	ppm	ASTM D5185m	>20	5		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.35		



50 64 (40°C) 48 (40°C) 44 42 Abnormal 40. Jan2/24

OIL ANALYSIS REPORT

VISUAL



	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	LIGHT		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
/24 +	Appearance	scalar	*Visual	NORMI	NORMI		
Jan2	Odor	scalar	*Visual	NORMI	NORMI		
	Emulsified Water	scalar	*Visual	>0.8	NEG		
	Free Water	scalar	*Visual	20.0	NEG		
		oodidi	1 locial			_	_
	FLUID PROPER I	IES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	46	46.3		
	SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Jan2.2.4	Color					no image	no image
	Bottom					no image	no image
	Non-ferrous Metal	S		Jan224			
	Viscosity @ 40°C			(D)HOU (D)HOU aumun picture Void Void Void Void Void Void Void Void	Acid Number		
Certificate 12367 Certificate 12367 Certificate 12367	: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0886218 Recieved : 16 Jan 2024 203 AERO COL : 06061324 Diagnosed : 17 Jan 2024 GREENSBORO, : 10832706 Diagnostician : Don Baldridge US 27 : IND 2 Contact: Dallas Burch antact Customer Service at 1-800-237-1369 dallas burcham@fs-compression						SION CO, LLC AERO COURT ENSBORO, NC US 27409 Dallas Burcham marcocian com
Certificate L2367 To discuss this sample report, c * - Denotes test methods that an Statements of conformity to speci	: 10832706 : IND 2 contact Customer Servi re outside of the ISO 1 ifications are based on tl	Diagnosti ice at 1-80 7025 scop he simple	ician : Dor 00-237-1369 pe of accred acceptance c	Baldridge D. itation. lecision rule (dallas.b (JCGM 106:2012)	Contact: I urcham@fs-co T: F:	US 274 Dallas Burcha mpression.cc (336)605-96 (336)605-98

Contact/Location: Dallas Burcham - AIRGREWC