




OIL ANALYSIS REPORT

Sample Rating Trend

DIRT



Area
(PORT SIDE) MACHINERY
Machine Id
CATERPILLAR JCS PORT
Component
Marine Diesel
Fluid
{not provided} (--- GAL)



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Elemental level of silicon (Si) above normal indicating ingress of seal material.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		DC0011505	---	---
Sample Date	Client Info		06 Jan 2024	---	---
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			SEVERE	---	---

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>5	<1.0	---	---
Water	WC Method	>0.1	NEG	---	---
Glycol	WC Method		NEG	---	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >80	62	---	---
Chromium	ppm	ASTM D5185m >14	<1	---	---
Nickel	ppm	ASTM D5185m >3	<1	---	---
Titanium	ppm	ASTM D5185m >2	<1	---	---
Silver	ppm	ASTM D5185m >2	0	---	---
Aluminum	ppm	ASTM D5185m >10	5	---	---
Lead	ppm	ASTM D5185m >11	0	---	---
Copper	ppm	ASTM D5185m >25	3	---	---
Tin	ppm	ASTM D5185m >2	0	---	---
Vanadium	ppm	ASTM D5185m	0	---	---
Cadmium	ppm	ASTM D5185m	0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	---	---
Barium	ppm	ASTM D5185m	0	---	---
Molybdenum	ppm	ASTM D5185m	<1	---	---
Manganese	ppm	ASTM D5185m	<1	---	---
Magnesium	ppm	ASTM D5185m	31	---	---
Calcium	ppm	ASTM D5185m	2080	---	---
Phosphorus	ppm	ASTM D5185m	845	---	---
Zinc	ppm	ASTM D5185m	996	---	---
Sulfur	ppm	ASTM D5185m	3497	---	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	79	---	---
Sodium	ppm	ASTM D5185m >40	0	---	---
Potassium	ppm	ASTM D5185m >20	<1	---	---

INFRA-RED




	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	---	---
Nitration	Abs/cm	*ASTM D7624 >20	5.7	---	---
Sulfation	Abs/.1mm	*ASTM D7415 >30	15.1	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	8.7	---	---
Base Number (BN)	mg KOH/g	ASTM D2896	9.44	---	---











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.7	---	---

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0011505 **Recieved** : 16 Jan 2024
Lab Number : 06061399 **Diagnosed** : 17 Jan 2024
Unique Number : 10832781 **Diagnostician** : Jonathan Hester
Test Package : MOB 2

JOHNSONS CRANE
 11708 OLD BALTIMORE PIKE
 BELTSVILLE, MD
 US 20705
 Contact: SERVICE MANAGER
 dispatch@jcsmd.net
 T:
 F: (301)937-5844

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)