




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
B44598 (S/N NFXYZ1)

Component
West Hydraulic System

Fluid
PETRO CANADA AW (60 GAL)

DIAGNOSIS

▲ Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0894809	---	---
Sample Date	Client Info	09 Jan 2024	---	---
Machine Age	hrs	Client Info	200	---
Oil Age	hrs	Client Info	50	---
Oil Changed	Client Info	N/A	---	---
Sample Status		ABNORMAL	---	---

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	3	---
Chromium	ppm	ASTM D5185m >20	<1	---
Nickel	ppm	ASTM D5185m >20	0	---
Titanium	ppm	ASTM D5185m	<1	---
Silver	ppm	ASTM D5185m	0	---
Aluminum	ppm	ASTM D5185m >20	2	---
Lead	ppm	ASTM D5185m >20	0	---
Copper	ppm	ASTM D5185m >20	<1	---
Tin	ppm	ASTM D5185m >20	<1	---
Vanadium	ppm	ASTM D5185m	0	---
Cadmium	ppm	ASTM D5185m	0	---

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	---
Barium	ppm	ASTM D5185m	0	---
Molybdenum	ppm	ASTM D5185m	0	---
Manganese	ppm	ASTM D5185m	0	---
Magnesium	ppm	ASTM D5185m	0	---
Calcium	ppm	ASTM D5185m	<1	---
Phosphorus	ppm	ASTM D5185m	444	---
Zinc	ppm	ASTM D5185m	0	---
Sulfur	ppm	ASTM D5185m	502	---

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	2	---
Sodium	ppm	ASTM D5185m	0	---
Potassium	ppm	ASTM D5185m >20	1	---
Water	%	ASTM D6304 >0.05	0.020	---
ppm Water	ppm	ASTM D6304 >500	208	---

FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	▲ 226603	---	---
Particles >6µm	ASTM D7647 >1300	▲ 56651	---	---
Particles >14µm	ASTM D7647 >160	▲ 14163	---	---
Particles >21µm	ASTM D7647 >40	▲ 1055	---	---
Particles >38µm	ASTM D7647 >10	▲ 263	---	---
Particles >71µm	ASTM D7647 >3	▲ 66	---	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 25/23/21	---	---

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.19	---



OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	---	---
Yellow Metal	scalar	*Visual	NONE	NONE	---	---
Precipitate	scalar	*Visual	NONE	NONE	---	---
Silt	scalar	*Visual	NONE	NONE	---	---
Debris	scalar	*Visual	NONE	LIGHT	---	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---	---
Appearance	scalar	*Visual	NORML	NORML	---	---
Odor	scalar	*Visual	NORML	NORML	---	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---	---
Free Water	scalar	*Visual		NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45.0	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0894809 **Received** : 16 Jan 2024
Lab Number : 06061920 **Tested** : 06 Feb 2024
Unique Number : 10833302 **Diagnosed** : 06 Feb 2024 - Doug Bogart
Test Package : IND 2 (Additional Tests: KF)

OSCEOLA FOODS (HORMEL)
 1027 WARREN AVE
 OSCEOLA, IA
 US 50213
 Contact: WADE MYERS
 wlmyers@hormel.com
 T: (641)342-8043
 F: (641)342-8047

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)