


OIL ANALYSIS REPORT

Aji-Tein Machine Id CS-3501C

Component Lube System

HIGH PERFORMANCE LUBRICANTS TURBINE LIFE 46 (14 GAL)



DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

🔺 Wear

The iron level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

Sample Number		Client Info		WC0870650	WC0804738	WC0804734
Sample Date		Client Info		10 Jan 2024	14 Sep 2023	23 Jun 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	1110	Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
-			11 11 11		-	
WEAR METALS		method	limit/base		history1	history2
Iron	ppm	ASTM D5185m	>20	<u> </u>	A 85	<u> </u>
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>10	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	0	0
Lead	ppm	ASTM D5185m	>10	<1	0	<1
Copper	ppm	ASTM D5185m		21	11	5
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	<1
Molybdenum	ppm	ASTM D5185m		<1	0	<1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		3	5	8
Calcium	ppm	ASTM D5185m		2	4	3
Phosphorus	ppm	ASTM D5185m		220	214	211
Zinc	ppm	ASTM D5185m		50	37	29
Sulfur	ppm	ASTM D5185m		18714	20883	20981
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>20	0	<1	<1
Sodium	ppm	ASTM D5185m		<1	9	8
Potassium	ppm	ASTM D5185m	>20	2	<1	2
Water	%	ASTM D6304	>0.1	0.003	0.004	0.004
ppm Water	ppm	ASTM D6304	>1000	38	45.8	45.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>640	A 2520	▲ 862	▲ 3329
Particles >6µm		ASTM D7647	>160	<u> </u>	▲ 335	1 118
Particles >14µm		ASTM D7647	>40	6 5	4 1	1 70
Particles >21µm		ASTM D7647	>10	<u> </u>	 11	11
Particles >38µm		ASTM D7647	>3	0	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>16/14/12	1 9/17/13	▲ 17/16/13	▲ 19/17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.51	0.49	0.52
	ing NOTI/g	A01WI D0040	0.13	0.51	0.43	0.52



Pio QCI

0.00

12000

10000

800

600

4000

2000

Abnorma

Water (ppm)

Bas

Sep19/18


01/11

Water (KF)

Vlar18/20

Jec16/20


OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history1	history2
VISUAL		memou	IIIIII/Dase	Current	TIStory	TIStoryz
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT		mothod	limit/base	ourroat	biotoput	biotory ()
	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	49.4	48.0	48.3
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color				a.		

Bottom





* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367