




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
VILTER CCUP-FGC

Component
Compressor
Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

MPC (Membrane Patch Colorimetry) test indicates acceptable levels of varnish present. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

Linear Sweep Voltammetry (RULER – ASTM D6971) testing indicates normal levels of anti-oxidants present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0896671	WC0782163	WC0782157
Sample Date	Client Info		16 Jan 2024	13 Sep 2023	07 Jun 2023
Machine Age	hrs	Client Info	104000	82000	38444
Oil Age	hrs	Client Info	104000	0	22444
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>5	<1	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>15	2	0	0
Lead	ppm	ASTM D5185m	>65	0	0	0
Copper	ppm	ASTM D5185m	>65	<1	0	0
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		46	23	31
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		182	274	281

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>35	0	0	0
Sodium	ppm	ASTM D5185m		0	<1	<1
Potassium	ppm	ASTM D5185m	>20	1	0	<1
Water	%	ASTM D6304	>0.1	0.004	0.004	0.002
ppm Water	ppm	ASTM D6304	>1000	50	49.1	16.0


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	1203	730	417
Particles >6µm	ASTM D7647	>2500	428	215	154
Particles >14µm	ASTM D7647	>320	66	19	17
Particles >21µm	ASTM D7647	>80	24	4	7
Particles >38µm	ASTM D7647	>20	2	0	2
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	17/16/13	17/15/11	16/14/11




OIL ANALYSIS REPORT


Remaining Life (RULER)




Varnish Potential




Particle Count



Acid Number



Water (KF)



FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.082	0.166	0.10
Anti-Oxidant 1	%	ASTM D6971	83	31	74
Anti-Oxidant 2	%	ASTM D6971	69	61	62
MPC Varnish Potential	Scale	ASTM D7843	8	53	47

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	102	102	102


SAMPLE IMAGES



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0896671 **Received** : 16 Jan 2024
Lab Number : **06061956** **Diagnosed** : 01 Feb 2024
Unique Number : 10833338 **Diagnostician** : Doug Bogart
Test Package : AOM 1 (Additional Tests: KF)

NORTH CAROLINA STATE UNIVERSITY
 621 MOTOR POOL DR, FACILITIES DIVISION WAREHOUSE
 RALEIGH, NC
 US 27607
 Contact: PAUL WALKER
 apwalke3@ncsu.edu
 T: (919)513-3646
 F:


To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)



MPC (Varnish Test)



Sample Color & Clarity



This page left intentionally blank