


# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**KAESER SK 20 7261606 (S/N 1420)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KC111118</b>	KC106073	KC107284
Sample Date	Client Info	<b>11 Sep 2023</b>	03 Mar 2023	19 May 2022
Machine Age	hrs	<b>22565</b>	20391	16442
Oil Age	hrs	<b>6123</b>	3949	9057
Oil Changed	Client Info	<b>Changed</b>	Not Changd	Changed
Sample Status		<b>ABNORMAL</b>	ABNORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<b>&lt;1</b>	<1	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m >10	<b>1</b>	<1	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>5</b>	2	3
Tin	ppm	ASTM D5185m >10	<b>0</b>	<1	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 90	<b>46</b>	15	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m 90	<b>47</b>	54	40
Calcium	ppm	ASTM D5185m 2	<b>2</b>	1	0
Phosphorus	ppm	ASTM D5185m	<b>11</b>	2	6
Zinc	ppm	ASTM D5185m	<b>0</b>	7	0

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	<b>&lt;1</b>	<1	<1
Sodium	ppm	ASTM D5185m	<b>14</b>	21	<1
Potassium	ppm	ASTM D5185m >20	<b>2</b>	9	3
Water	%	ASTM D6304 >0.05	<b>0.016</b>	0.016	0.023
ppm Water	ppm	ASTM D6304 >500	<b>164</b>	164.2	234.0

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>33666</b>	27086	4584
Particles >6µm	ASTM D7647 >1300	<b>▲ 11739</b>	▲ 10528	748
Particles >14µm	ASTM D7647 >80	<b>▲ 1023</b>	▲ 1013	74
Particles >21µm	ASTM D7647 >20	<b>▲ 284</b>	▲ 208	24
Particles >38µm	ASTM D7647 >4	<b>▲ 14</b>	▲ 16	2
Particles >71µm	ASTM D7647 >3	<b>1</b>	0	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	<b>▲ 22/21/17</b>	▲ 22/21/17	19/17/13

## FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.36</b>	0.34	0.35

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### Water (KF)




### Acid Number



### Water (KF)



### Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>LIGHT</b>	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	VLITE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML
Emulsified Water	scalar	*Visual	>0.05	<b>NEG</b>	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	<b>49.4</b>	45.8	45.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC111118 **Received** : 16 Jan 2024  
**Lab Number** : 06062011 **Diagnosed** : 18 Jan 2024  
**Unique Number** : 10833393 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2

**PERFORMANCE SPORTS SYSTEMS**  
 9200 EAST 146TH ST, SUITE A  
 NOBLESVILLE, IN  
 US 46060  
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: