

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
NEW I/R
Component
Air Compressor
Fluid

{not provided} (--- GAL)

רו	ΙΔ	(-1)	V۲	15	SIS
	-	uі.	W	ノし	טוכ

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jan 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0005066		
Sample Date		Client Info		15 Jan 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>4	0		
Nickel	ppm	ASTM D5185m	>4	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>10	1		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>40	0		
Tin	ppm	ASTM D5185m	>5	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Vagnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		12		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
Nater	%	ASTM D6304	>0.6	0.003		
ppm Water	ppm	ASTM D6304	>6000	31		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1356		
Particles >6µm		ASTM D7647	>2500	403		
Particles >14µm		ASTM D7647	>320	38		
Particles >21µm		ASTM D7647	>80	10		
Particles >38µm		ASTM D7647	>20	0		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	18/16/12		
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
A aid Number (ANI)	1/01//	ACTM DOOM		0.17		


Acid Number (AN)

mg KOH/g ASTM D8045

0.17



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number Unique Number

Test Package

: USP0005066 : 06062032

: 10833414

: 16 Jan 2024 Recieved Diagnosed : 18 Jan 2024 : Jonathan Hester Diagnostician

1001 E. SMITH STREET

CALIFORNIA, MO US 65018

Contact: REFRIGERATION DEPT.

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (573)796-3661

Contact/Location: REFRIGERATION DEPT. - CARCALMO

T: (573)796-7154