

## **OIL ANALYSIS REPORT**

Area ACAS-115 Machine Id INGERSOLL RAND PX5229U05160 Component

Compressor

### DIAGNOSIS

#### Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

#### 🔺 Wear

The copper level is abnormal. All other component wear rates are normal.

#### Contamination

There is a moderate concentration of water present in the oil.

#### Fluid Condition

The AN level is above the recommended limit.

				Dec2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06062095		
Sample Date		Client Info		21 Dec 2023		
Machine Age	hrs	Client Info		15314		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	3		
Copper	ppm	ASTM D5185m	>50	<u> </u>		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		206		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		6		
Calcium	ppm	ASTM D5185m		18		
Phosphorus	ppm	ASTM D5185m		6		
Zinc	ppm	ASTM D5185m		384		
Sulfur	ppm	ASTM D5185m		301		
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		35		
Potassium	ppm	ASTM D5185m	>20	4		
Water	%	ASTM D6304	>0.1	<u> </u>		
ppm Water	ppm	ASTM D6304	>1000	<b>6170</b>		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>2.60</b>		


WATER




35

Dec21/

# **OIL ANALYSIS REPORT**





Certificate L2367

Contact/Location: JIM SUAREZ - UCADVTOM