




# PROBLEM SUMMARY

Sample Rating Trend



**WEAR**




## Machine Id SULLAIR PAM 1 GAS


Component  
**Screw Compressor**  
Fluid  
**CAMCO 91-46 HT (5 GAL)**

### COMPONENT CONDITION SUMMARY

Aluminum (ppm)



Viscosity @ 40°C



### RECOMMENDATION

The oil filtered at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

### PROBLEMATIC TEST RESULTS

Sample Status	SEVERE	SEVERE	ATTENTION
Aluminum	ppm ASTM D5185m >5 <b>96</b>	49	<1

Customer Id: ATIMONNC  
Sample No.: WC0730024  
Lab Number: 06062108  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

25 Apr 2023 Diag: Jonathan Hester

WEAR



Oil and filter change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. The aluminum level is severe. There is no indication of any contamination in the oil. The oil viscosity is higher than normal. Confirm oil type. The AN level is acceptable for this fluid.

view report



20 Jan 2023 Diag: Jonathan Hester

VISCOSITY



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The oil viscosity is higher than normal. Confirm oil type. The AN level is acceptable for this fluid.

view report



19 Oct 2022 Diag: Jonathan Hester

VISCOSITY



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The oil viscosity is higher than normal. Confirm oil type. The AN level is acceptable for this fluid.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Machine Id  
**SULLAIR PAM 1 GAS**

Component  
**Screw Compressor**  
Fluid  
**CAMCO 91-46 HT (5 GAL)**

## DIAGNOSIS

### Recommendation

The oil filtered at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

### Wear

The aluminum level is severe.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The oil viscosity is higher than normal. Confirm oil type. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0730024</b>	WC0749063	WC0749065
Sample Date	Client Info		<b>22 Dec 2023</b>	25 Apr 2023	20 Jan 2023
Machine Age	days	Client Info	<b>0</b>	0	15
Oil Age	days	Client Info	<b>0</b>	21	15
Oil Changed	Client Info		<b>Filtered</b>	Changed	Changed
Sample Status			<b>SEVERE</b>	SEVERE	ATTENTION

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >60	<b>2</b>	4	3
Chromium	ppm	ASTM D5185m >4	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >5	<b>96</b>	<b>49</b>	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >30	<b>5</b>	2	<1
Tin	ppm	ASTM D5185m >15	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	2
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Calcium	ppm	ASTM D5185m	<b>3</b>	0	0
Phosphorus	ppm	ASTM D5185m	<b>12</b>	13	17
Zinc	ppm	ASTM D5185m	<b>142</b>	79	55
Sulfur	ppm	ASTM D5185m	<b>381</b>	374	579

## CONTAMINANTS


	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>&lt;1</b>	1	1
Sodium	ppm	ASTM D5185m	<b>0</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	0

## FLUID DEGRADATION


	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.151</b>	0.05	0.056

# OIL ANALYSIS REPORT


**Aluminum (ppm)**



**Viscosity @ 40°C**



**Acid Number**







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	▲ 62.7	▲ 59.6	▲ 64.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0730024 **Recieved** : 16 Jan 2024  
**Lab Number** : 06062108 **Diagnosed** : 18 Jan 2024  
**Unique Number** : 10833490 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2

**ATI METALS - BAKERS - BNO**  
 6400 ALLOY WAY  
 MONROE, NC  
 US 28111  
 Contact: JODEY BIRCHMORE  
 jodey.birchmore@atimetals.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: