




# PROBLEM SUMMARY

Sample Rating Trend




WATER



Machine Id  
**T001-02**  
 Component  
**Hydraulic System**  
 Fluid  
**ERIFON 818 (--- GAL)**

## COMPONENT CONDITION SUMMARY

### ▲ Ferrous Alloys



## RECOMMENDATION

We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

| Sample Status    |        |             |       | SEVERE | NORMAL | ABNORMAL |
|------------------|--------|-------------|-------|--------|--------|----------|
| Iron             | ppm    | ASTM D5185m | >20   | ▲ 39   | 5      | 0        |
| Emulsified Water | scalar | *Visual     | >0.05 | ◆ 0.2% | 0.2%   | NEG      |
| PrtFilter        |        |             |       |        |        |          |

Customer Id: PAREUG  
 Sample No.: PH0001547  
 Lab Number: 06062633  
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

RECOMMENDED ACTIONS

| Action   | Status | Date | Done By | Description   |
|----------|--------|------|---------|---|
| Resample | ---    | ---  | ?       | We recommend an early resample to monitor this condition. |

HISTORICAL DIAGNOSIS

20 Oct 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The pH level of this fluid is within the acceptable limits. pH is 9.10. The condition of the oil is suitable for further service.

view report



29 Jun 2023 Diag: Doug Bogart

DEGRADATION



We recommend an early resample to monitor this condition. Please submit a sample of the new (unused) oil to establish a baseline. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is above the recommended limit.

view report



17 Apr 2023 Diag: Jonathan Hester

DEGRADATION



We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is above the recommended limit. The oil is no longer serviceable.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id  
**T001-02**  
 Component  
**Hydraulic System**  
 Fluid  
**ERIFON 818 (--- GAL)**

## DIAGNOSIS

### Recommendation

We recommend an early resample to monitor this condition.

### Wear

The iron level is abnormal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The pH level of this fluid is within the acceptable limits at 9.0. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

|               | method      | limit/base  | current            | history1    | history2    |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info |             | <b>PH0001547</b>   | PH0001554   | PH0000638   |
| Sample Date   | Client Info |             | <b>05 Jan 2024</b> | 20 Oct 2023 | 29 Jun 2023 |
| Machine Age   | hrs         | Client Info | <b>0</b>           | 0           | 0           |
| Oil Age       | hrs         | Client Info | <b>0</b>           | 0           | 0           |
| Oil Changed   | Client Info |             | <b>N/A</b>         | N/A         | N/A         |
| Sample Status |             |             | <b>SEVERE</b>      | NORMAL      | ABNORMAL    |

## WEAR METALS

|          | method | limit/base      | current      | history1 | history2 |
|----------|--------|-----------------|--------------|----------|----------|
| Iron     | ppm    | ASTM D5185m >20 | <b>▲ 39</b>  | 5        | 0        |
| Chromium | ppm    | ASTM D5185m >20 | <b>&lt;1</b> | <1       | 0        |
| Nickel   | ppm    | ASTM D5185m >20 | <b>2</b>     | <1       | 0        |
| Titanium | ppm    | ASTM D5185m     | <b>0</b>     | <1       | 0        |
| Silver   | ppm    | ASTM D5185m     | <b>0</b>     | 0        | 0        |
| Aluminum | ppm    | ASTM D5185m >20 | <b>9</b>     | 14       | 0        |
| Lead     | ppm    | ASTM D5185m >20 | <b>&lt;1</b> | 0        | 0        |
| Copper   | ppm    | ASTM D5185m >20 | <b>&lt;1</b> | <1       | 0        |
| Tin      | ppm    | ASTM D5185m >20 | <b>1</b>     | <1       | 0        |
| Vanadium | ppm    | ASTM D5185m     | <b>&lt;1</b> | 1        | <1       |
| Cadmium  | ppm    | ASTM D5185m     | <b>&lt;1</b> | <1       | 0        |

## ADDITIVES

|            | method | limit/base  | current      | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron      | ppm    | ASTM D5185m | <b>20</b>    | 10       | 0        |
| Barium     | ppm    | ASTM D5185m | <b>0</b>     | 0        | 0        |
| Molybdenum | ppm    | ASTM D5185m | <b>0</b>     | <1       | 0        |
| Manganese  | ppm    | ASTM D5185m | <b>&lt;1</b> | 0        | 0        |
| Magnesium  | ppm    | ASTM D5185m | <b>3</b>     | 0        | <1       |
| Calcium    | ppm    | ASTM D5185m | <b>13</b>    | <1       | 0        |
| Phosphorus | ppm    | ASTM D5185m | <b>359</b>   | 1903     | 793      |
| Zinc       | ppm    | ASTM D5185m | <b>0</b>     | 0        | 0        |
| Sulfur     | ppm    | ASTM D5185m | <b>263</b>   | 17       | 0        |

## CONTAMINANTS

|           | method | limit/base       | current       | history1 | history2 |
|-----------|--------|------------------|---------------|----------|----------|
| Silicon   | ppm    | ASTM D5185m >15  | <b>3</b>      | 3        | <1       |
| Sodium    | ppm    | ASTM D5185m      | <b>89</b>     | 77       | 0        |
| Potassium | ppm    | ASTM D5185m >20  | <b>15</b>     | 12       | 0        |
| Water     | %      | ASTM D6304 >0.05 | <b>34.2</b>   | 35.1     | 0.005    |
| ppm Water | ppm    | ASTM D6304 >500  | <b>342000</b> | 351000   | 50       |

## FLUID CLEANLINESS

|                 | method       | limit/base | current         | history1 | history2   |
|-----------------|--------------|------------|-----------------|----------|------------|
| Particles >4µm  | ASTM D7647   | >10000     | <b>2775</b>     | 2097     | 3515       |
| Particles >6µm  | ASTM D7647   | >2500      | <b>1512</b>     | 1142     | 1915       |
| Particles >14µm | ASTM D7647   | >320       | <b>257</b>      | 194      | ▲ 326      |
| Particles >21µm | ASTM D7647   | >80        | <b>87</b>       | 65       | ▲ 110      |
| Particles >38µm | ASTM D7647   | >20        | <b>13</b>       | 10       | 17         |
| Particles >71µm | ASTM D7647   | >4         | <b>1</b>        | 1        | 2          |
| Oil Cleanliness | ISO 4406 (c) | >20/18/15  | <b>19/18/15</b> | 18/17/15 | ▲ 19/18/16 |


## FLUID DEGRADATION

|                  | method   | limit/base | current      | history1 | history2 |
|------------------|----------|------------|--------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | <b>5.653</b> | 6.25     | ▲ 4.888  |




# OIL ANALYSIS REPORT


### ▲ Ferrous Alloys




### Particle Count




### Acid Number



### Water (KF)



### Viscosity @ 40°C



| VISUAL           | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Yellow Metal     | scalar | *Visual    | NONE    | NONE     | NONE     |
| Precipitate      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Silt             | scalar | *Visual    | NONE    | NONE     | NONE     |
| Debris           | scalar | *Visual    | NONE    | NONE     | NONE     |
| Sand/Dirt        | scalar | *Visual    | NONE    | NONE     | NONE     |
| Appearance       | scalar | *Visual    | NORML   | NORML    | NORML    |
| Odor             | scalar | *Visual    | NORML   | NORML    | NORML    |
| Emulsified Water | scalar | *Visual    | >0.05   | 0.2%     | NEG      |
| Free Water       | scalar | *Visual    |         | NEG      | NEG      |

| FLUID PROPERTIES | method     | limit/base | current | history1 | history2 |
|------------------|------------|------------|---------|----------|----------|
| pH               | Scale 0-14 | ASTM D1287 | 9.00    | 9.10     | ---      |
| Visc @ 40°C      | cSt        | ASTM D445  | 24.8    | 22.2     | 22.1     |

### SAMPLE IMAGES

|           | method | limit/base | current | history1 | history2 |
|-----------|--------|------------|---------|----------|----------|
| Color     |        |            |         |          |          |
| Bottom    |        |            |         |          |          |
| PrfFilter |        |            |         |          |          |



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PH0001547 **Received** : 17 Jan 2024  
**Lab Number** : 06062633 **Tested** : 26 Jan 2024  
**Unique Number** : 10834015 **Diagnosed** : 05 Feb 2024 - Doug Bogart  
**Test Package** : PLANT ( Additional Tests: KF, pH, PrfFilter )

**PARKER HANNIFIN CORPORATION**  
 29289 AIRPORT RD  
 EUGENE, OR  
 US 97402  
 Contact: JASON MYERS  
 jason.myers@parker.com

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)