




OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
TR-3
 Component
Hydraulic System
 Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC06062684	WC06043240	WC05605118
Sample Date	Client Info		15 Jan 2024	20 Dec 2023	28 Jul 2022
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	2	3	3
Chromium	ppm	ASTM D5185m >20	0	<1	0
Nickel	ppm	ASTM D5185m >20	0	0	0
Titanium	ppm	ASTM D5185m	7	11	<1
Silver	ppm	ASTM D5185m	0	0	<1
Aluminum	ppm	ASTM D5185m >20	1	3	<1
Lead	ppm	ASTM D5185m >20	0	0	<1
Copper	ppm	ASTM D5185m >20	1	3	4
Tin	ppm	ASTM D5185m >20	<1	0	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<1	1	1
Barium	ppm	ASTM D5185m	0	0	29
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	0	0	<1
Magnesium	ppm	ASTM D5185m	<1	<1	0
Calcium	ppm	ASTM D5185m	9	19	37
Phosphorus	ppm	ASTM D5185m	334	337	195
Zinc	ppm	ASTM D5185m	0	0	7
Sulfur	ppm	ASTM D5185m	4352	4595	3944

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<1	<1	<1
Sodium	ppm	ASTM D5185m	1	0	4
Potassium	ppm	ASTM D5185m >20	1	3	5
Water	%	ASTM D6304 >0.05	0.005	0.010	0.019
ppm Water	ppm	ASTM D6304 >500	59	102	193.9






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 103710	▲ 116082	▲ 136222
Particles >6µm	ASTM D7647	>1300	▲ 17815	▲ 21898	▲ 33392
Particles >14µm	ASTM D7647	>160	▲ 223	▲ 167	▲ 2068
Particles >21µm	ASTM D7647	>40	▲ 53	16	▲ 393
Particles >38µm	ASTM D7647	>10	3	0	▲ 30
Particles >71µm	ASTM D7647	>3	0	0	2
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 24/21/15	▲ 24/22/15	▲ 24/22/18

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.78	0.76	0.60

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	17.5	22.5	27.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC06062684 **Received** : 17 Jan 2024
Lab Number : 06062684 **Diagnosed** : 19 Jan 2024
Unique Number : 10834066 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF)

METALUBE INC
 56 CYPRESS DR
 YOUNGSVILLE, NC
 US 27596
 Contact: CHRIS BARNES
 cbarnes@metalubeinc.com
 T: (919)554-3024
 F: (919)554-3023

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)