

OIL ANALYSIS REPORT


WH-100

B25970 - STORK COOKER GEARBOX #6 (1ST ON CHILL SECTION)

Component

Gearbox

PETRO CANADA ENDURATEX WG 680 (---



Sample Rating Trend



Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 6 microns in size) present in the oil.

▲ Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

GAL)		ay2017 Jan2	020 Jul2020 Jun2021	Jan2022 Jul2022 Feb2023	Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0880591	WC0856020	WC0826080
Sample Date		Client Info		10 Jan 2024	29 Nov 2023	25 Jul 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	30	20	17
Chromium	ppm	ASTM D5185m	>15	<1	0	0
Nickel	ppm	ASTM D5185m	>15	0	<1	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	0	0
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	13	10	9
Tin	ppm	ASTM D5185m	>25	0	0	<1
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	1	0	0	0
Barium	ppm	ASTM D5185m	1	3	0	0
Molybdenum	ppm	ASTM D5185m	1	0	0	0
Manganese	ppm	ASTM D5185m	1	0	<1	0
Magnesium	ppm	ASTM D5185m	1	0	0	0
Calcium	ppm	ASTM D5185m	1	0	<1	0
Phosphorus	ppm	ASTM D5185m	1	48	<1	7
Zinc	ppm	ASTM D5185m	1	0	20	0
Sulfur	ppm	ASTM D5185m	3114	3126	2469	3221
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	1	<1	<1
Sodium	ppm	ASTM D5185m		0	1	<1
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.2	0.059		
ppm Water	ppm	ASTM D6304	>2000	590		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	11474	▲ 323762	<u>^</u> 264025
Particles >6µm		ASTM D7647	>2500	1171	194699	<u>227458</u>
Particles >14µm		ASTM D7647	>320	33	4 071	△ 66270
Particles >21µm		ASTM D7647	>80	10	<u></u> 113	△ 7698
Particles >38µm		ASTM D7647	>20	1	1	3
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	2 1/17/12	2 6/25/19	▲ 25/25/23
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.43	1.56	1.61	1.44



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: WC0880591 : 06063556 : 10834938

Recieved : 17 Jan 2024 Diagnosed : 24 Jan 2024

Diagnostician : Doug Bogart Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 1101 NORTH MAIN ST

AUSTIN, MN US 55912 Contact: RYAN LOWE

rslowe@hormel.com T: (507)437-5674 F: (507)437-9805