

OIL ANALYSIS REPORT


FP-010

B24610 - CONVEYOR KSI INCLINE SCREW RAW PROD #6

Component

Auger

GAL) PETRO CANADA SYNDURO SHB ISO 460 (-





ט	IA	G	N	U	S	IS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Gear wear is indicated. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

(GAL)		Jan2022 Ap	2022 Jul2022 Nov2022	Jan2023 Apr2023 Jul2023 Oct20	23 Jan2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0880561	WC0850222	WC0820609
Sample Date		Client Info		09 Jan 2024	08 Oct 2023	05 Jul 2023
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>150	278	147	89
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>10	0	0	0
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	0	1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>50	2	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	5.0	3	1	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		2	1	<1
Magnesium	ppm	ASTM D5185m	5.0	2	4	1
Calcium	ppm	ASTM D5185m	5.0	13	7	<1
Phosphorus	ppm	ASTM D5185m	60	145	94	102
Zinc	ppm	ASTM D5185m	5.0	0	2	0
Sulfur	ppm	ASTM D5185m	1900	2464	2122	2800
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<u>^</u> 72	22	5
Sodium	ppm	ASTM D5185m		13	10	<1
Potassium	ppm	ASTM D5185m	>20	20	9	2
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	<u>▲</u> 309782	<u>^</u> 230244	<u>^</u> 286006
Particles >6μm		ASTM D7647	>2500	<u> </u>	<u>▲</u> 141096	▲ 97391
Particles >14μm		ASTM D7647	>320	<u> </u>	<u>▲</u> 5610	<u>1713</u>
Particles >21µm		ASTM D7647	>80	<u> </u>	<u> 1008</u>	<u>406</u>
Particles >38μm		ASTM D7647	>20	4	14	7
Particles >71μm		ASTM D7647	>4	2	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>25/25/21</u>	<u>\$\times\$ 25/24/20</u>	<u>\$\text{\Delta}\$ 25/24/18</u>
FLUID DEGRADA	TION	method	limit/base		history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.3	0.77	0.48	0.29



OIL ANALYSIS REPORT







Certificate L2367

Lab Number **Unique Number**

: 06063559

: 10834941

Diagnosed

: 19 Jan 2024 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

AUSTIN, MN US 55912 Contact: RYAN LOWE

rslowe@hormel.com T: (507)437-5674 F: (507)437-9805

Contact/Location: RYAN LOWE - HORAUS