

# **OIL ANALYSIS REPORT**

## Sample Rating Trend



**NORMAL** 



# ENGINE ROOM 40-3 (S/N S1627)

**Refrigeration Compressor** 

**USPI ALT-68 SC (150 GAL)** 

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

2015 Jan2016 Jan2017 Jan2018 Nov2018 Aug2019 Aug2020 Aug2021 Jul2022 Jul2023						
SAMPLE INFORM	MOITAN	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0004814	USP0001098	USP250205
Sample Date		Client Info		04 Jan 2024	11 Oct 2023	05 Jul 2023
Machine Age	hrs	Client Info		46900	46138	45393
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	0
Chromium	ppm	ASTM D5185m	>2	<1	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	<1
Lead	ppm	ASTM D5185m	>2	0	0	<1
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	0	<1
Water	%	ASTM D6304	>0.01	0.002	0.002	0.001
ppm Water	ppm	ASTM D6304	>100	25	15.3	11.5
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	4727	2259	2381
Particles >6µm		ASTM D7647	>2500	763	756	451
Particles >14μm		ASTM D7647	>320	26	64	19
Particles >21µm		ASTM D7647	>80	5	10	3
Particles >38µm		ASTM D7647	>20	1	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/12	18/17/13	18/16/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.014	0.014	0.014



# **OIL ANALYSIS REPORT**





Certificate L2367

Lab Number Unique Number

Test Package : IND 2

: 06063611 : 10834993

Diagnosed Diagnostician

: 19 Jan 2024 : Doug Bogart NEWBERRY, SC US 29108 Contact:

T: F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)