

### **OIL ANALYSIS REPORT**

#### Sample Rating Trend

#### NORMAL

# 30-2 MYCOM ER2 (S/N 3251122)

Refrigeration Compressor

USPI ALT-68 SC (150 GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

ti i ti i i				
t e e e t é é				
- konservicion				
		an à na è 🛛 n	laéané lanén	
±2015 Jan2017	Jan2018 Nov2018	0ct2019 0ct2020	Jul2021 Jul2022 Apr2023	



SAMPLE INFORM	IATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		USP0004797	USP0001088	USP250199	
Sample Date		Client Info		03 Jan 2024	11 Oct 2023	06 Jul 2023	
Machine Age	hrs	Client Info		26222	25223	23388	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				NORMAL	NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>8	0	0	<1	
Chromium	ppm	ASTM D5185m	>2	<1	0	0	
Nickel	ppm	ASTM D5185m		0	0	0	
Titanium	ppm	ASTM D5185m		0	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	0	
Aluminum	ppm	ASTM D5185m	>3	0	0	<1	
Lead	ppm	ASTM D5185m	>2	0	0	<1	
Copper	ppm	ASTM D5185m		0	0	0	
Tin	ppm	ASTM D5185m	>4	0	0	0	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		0	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0	
Barium	ppm	ASTM D5185m		0	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	0	
Manganese	ppm	ASTM D5185m		0	0	0	
Magnesium	ppm	ASTM D5185m		0	0	0	
Calcium	ppm	ASTM D5185m		<1	0	0	
Phosphorus	ppm	ASTM D5185m		0	0	0	
Zinc	ppm	ASTM D5185m		0	0	0	
Sulfur	ppm	ASTM D5185m	50	0	1	0	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>15	0	0	0	
Sodium	ppm	ASTM D5185m		0	0	0	
Potassium	ppm	ASTM D5185m	>20	<1	<1	<1	
Water	%	ASTM D6304	>0.01	0.003	0.003	0.003	
ppm Water	ppm	ASTM D6304	>100	31	37.3	27.6	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>10000	1038	682	831	
Particles >6µm		ASTM D7647	>2500	213	143	102	
Particles >14µm		ASTM D7647	>640	24	11	8	
Particles >21µm		ASTM D7647	>160	6	2	4	
Particles >38µm		ASTM D7647	>40	0	0	0	
Particles >71µm		ASTM D7647	>10	0	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/16	17/15/12	17/14/11	17/14/10	
FLUID DEGRADATION method limit/base current history1 history2							
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.013	0.014	0.014	



Water (KF)

## **OIL ANALYSIS REPORT**

scalar


scalar


White Metal


Yellow Metal

\*Visual

\*Visual







NONE

NONE

NONE

NONE

NONE

NONE

NONE

NONE

250 200 Ē 150 Water 100 GRAPHS Ferrous Alloys n lct14/20 111/22 Viscosity @ 40°C 7 0. ul11/22 7 17/1 nb/ (40°C) Non-ferrous Metals š 60 55 Jul11/22 ct14/20 114/7 ul11/22 Dct7/ Particle Trend an1 100 Viscosity @ 40°C Ê 80 7! Ab Selo 60 70 ÷ 40 55


Jul11/22

Laboratory

Sample No.

Lab Number

Unique Number



Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 06063625

: 10835007

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician

: Doug Bogart

Jan 17/16

Vov20/1

an 22/1

: USP0004797

Certificate L2367

Contact/Location: ? ? - KRANEWUSP

T:

F: