




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
[SV2401090001]
 Machine Id
MCQUAY CAMDEN YARDS CHILLER 2 (S/N 58A81051-00)
 Component
Refrigeration Compressor
 Fluid
MOBIL EAL ARTIC ISO 46 (8 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0814433 | WC0525438 | WCI2322189 |
| Sample Date | Client Info | | 12 Jan 2024 | 01 Apr 2021 | 07 Jul 2020 |
| Machine Age | hrs | Client Info | 51550 | 48310 | 47720 |
| Oil Age | hrs | Client Info | 51550 | 48310 | 47720 |
| Oil Changed | Client Info | | Not Changed | Not Changd | Not Changed |
| Sample Status | | | NORMAL | MARGINAL | MARGINAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|------------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m >100 | 3 | 4 | 2 |
| Chromium | ppm | ASTM D5185m >2 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | 0 | 0 | <1 |
| Titanium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m >2 | 0 | <1 | 0 |
| Aluminum | ppm | ASTM D5185m >50 | 2 | 4 | 3 |
| Lead | ppm | ASTM D5185m >2 | <1 | 1 | <1 |
| Copper | ppm | ASTM D5185m >100 | 2 | 1 | 1 |
| Tin | ppm | ASTM D5185m >4 | <1 | <1 | 0 |
| Antimony | ppm | ASTM D5185m | --- | <1 | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | <1 | 3 | 2 |
| Barium | ppm | ASTM D5185m | 3 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 0 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Calcium | ppm | ASTM D5185m | <1 | <1 | 0 |
| Phosphorus | ppm | ASTM D5185m | 303 | 20 | 8 |
| Zinc | ppm | ASTM D5185m | 0 | 14 | 6 |
| Sulfur | ppm | ASTM D5185m | 0 | 2 | 8 |

CONTAMINANTS




| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >50 | 20 | 20 | 18 |
| Sodium | ppm | ASTM D5185m | 0 | 3 | 3 |
| Potassium | ppm | ASTM D5185m >20 | <1 | 0 | 0 |
| Water | % | ASTM D6304 >0.02 | 0.003 | ▲ 0.026 | ▲ 0.029 |
| ppm Water | ppm | ASTM D6304 >250 | 33 | ▲ 269.2 | ▲ 297.1 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|------------|--------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D974 | 0.028 | 0.016 | 0.032 |




OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.02 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 | |
|------------------|--------|------------|---------|-------------|----------|------|
| Visc @ 40°C | cSt | ASTM D445 | 49.2 | 41.0 | 43.6 | 41.8 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0814433 **Received** : 17 Jan 2024
Lab Number : 06063656 **Diagnosed** : 19 Jan 2024
Unique Number : 10835038 **Diagnostician** : Don Baldrige
Test Package : IND 2

DAIKIN APPLIED
 5021 HOWERTON WAY SUITE P
 BOWIE, MD
 US 20715
 Contact: ANDREW TURLINGTON
 andrew.turlington@daikinapplied.com
 T: (301)735-1440
 F: (301)735-1838

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)