


OIL ANALYSIS REPORT

NOT GIVEN Machine Id ELGI MNJS040004 - NORTH AMERICAN ASSEMBLIES

Component

Compressor





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


				Dec2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06063697		
Sample Date		Client Info		15 Dec 2023		
Machine Age	hrs	Client Info		25012		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		<1		
Phosphorus	ppm	ASTM D5185m		209		
Zinc	ppm	ASTM D5185m		7		
Sulfur	ppm	ASTM D5185m		834		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.45

Acid Number (AN) mg KOH/g ASTM D8045



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number Unique Number

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 06063697 : 10835079

(40°C)

: UCH06063697

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Viscosity @ 40°C

Recieved Diagnosed Diagnostician

: 17 Jan 2024 : 19 Jan 2024 : Don Baldridge

Dec15/23 -

FLUID FLOW 459 NORTH BROOKS ST MANNING, SC US 29102

Contact: TREY WEEKS treyweeks@fluidflow.com T:

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Acid Number

0.50 W 0.40

E 0.30 은 0.20 0.10 0.00

F: